



BACHELOR'S DEGREE IN ENGINEERING FOR INDUSTRIAL TECHNOLOGIES

Final Degree Project

LARGE SCALE PHOTOVOLTAIC SOLAR PLANT FEASIBILITY STUDY

Author: Miguel Córdoba Ocaña

Supervisor: Consolación Alonso Alonso

Madrid

August 2022

Declaro, bajo mi responsabilidad, que el Proyecto presentado con el título

“Large Scale Photovoltaic Solar Plant Feasibility Study”

en la ETS de Ingeniería - ICAI de la Universidad Pontificia Comillas en el curso académico 2021/2022 es de mi autoría, original e inédito y no ha sido presentado con anterioridad a otros efectos. El Proyecto no es plagio de otro, ni total ni parcialmente y la información que ha sido tomada de otros documentos está debidamente referenciada.

Fdo.: Miguel Córdoba Ocaña

Fecha: 26/08/2022



Autorizada la entrega del proyecto
EL DIRECTOR DEL PROYECTO

Fdo.: Consuelo Alonso Alonso

Fecha: 26/08/2022

ACKNOWLEDGEMENTS

To my beloved mother, father, sister, grandmother, aunt, uncle, cousins, and cousins in law for always encouraging me to give the best of myself.

To my Algebra professor Santiago Canales, my Fluid Mechanics professor Luis Mochón, and my friend Javier García for their great trust and support since our first acquaintance.

To my Electrical Protections professor Luis Rouco for providing me with paper-version electrical grid maps that enabled the achievement of this project.

To my Ethics professor Laura Gismera for her unconditional moral support since our first acquaintance.

To my neighbor Carmen del Pozo for showing a special interest in this Project.

To my supervisor Consuelo Alonso for her great help, trust, and support in my endeavors to achieve the main goals of this project.

LARGE SCALE PHOTOVOLTAIC SOLAR PLANT FEASIBILITY STUDY

Author: Córdoba Ocaña, Miguel

Supervisor: Alonso Alonso, Consolación

Collaborating Entity: ICAI - School of Engineering - Pontifical University of Comillas

ABSTRACT:

1. Introduction:

The photovoltaic effect is a physical phenomenon that consists of direct solar irradiance over a surface to generate electricity.

As of today, we have enhanced technology at our disposal to take advantage of this phenomenon to produce energy in a competitive market with a neutral carbon footprint. This technology is the main core of this Project. Namely, the generating solar panels that form the power plant.

The Project, with a 50.00 MWp capacity, is located within an 11.4 km radius of the electrical substation of Riega (transmission grid, 132 kV) in the province of Ciudad Real in Spain.

2. Development:

The main steps followed for this project were:

- a) Analyzing different solar irradiance data from solar bases (Meteonorm)
- b) Analyzing slopes in the terrain (Google Earth)
- c) Selecting the appropriate number of hectares (Google Earth)
- d) Selecting the electrical substation for energy injection (2018 R.E.E. Electrical Map)
- e) Energy Simulation for component selection (PVSyst program).
- f) Selecting the appropriate inverters
- g) Selecting the appropriate trackers
- h) Budgetary calculations
- i) Profitability analysis
- j) Project plans

3. Results:

The results obtained while analyzing and simulating were the following:

- Installed peak power (P_p): 50.00 MWp
- Inverters nominal power (P_n): 48.00 MWac

- Ratio (P_p / P_n): 1.042
- Overload loss: 0.0%
- Unitary bifacial photovoltaic solar panel nominal power: 530 W
- Yearly energy production: 99.9 GWh/year
- Yearly specific production: 1998 kWh/kWp/year
- Performance ratio: 85.27%
- Design overview:
 - Number of modules: 94338 (3494 strings of 27 modules each)
 - Module area: 241132 m²
 - Shed area: 242525 m²
 - Total physical area: 65.6 hectares
 - Number of trackers: 295
 - Number of inverters: 10
 - Number of transformation stages: 2

Where models for every element in the power plant are the following:

- Panels: LONGI SOLAR ‘LR5-72 HBD 530 MBD M Bifacial’, 530 Wp, 35 V, monocrystalline silicon (Si-mono)
- Inverters: SIEMENS ‘SINACON PV4800’, 4800 kW, 962-1500 V, 50/60 Hz
- Trackers: IDEEMATEC ‘SafeTrack H4plus bifacial’ (single-axis tracker)

Grid injection system elements:

- LV lines (per inverter):
 - Voltage: 660 V
 - Length: 9.2 m x 10 inverters
 - Loss fraction at STC: 0.08%
 - Wire section: 4000 mm²
 - Material: Aluminum
- MV Lines:
 - Voltage: 20 kV
 - Length: 1000 m x 4 lines
 - Loss fraction at STC: 0.32%
 - Wire section: 300 mm²
 - Material: Aluminum
 - Covering: XLPE
 - Manufacturer: ‘Eland Cables’
 - Model: ‘YMz1Krvasdlwd-AL 12/20kV Cable’

- HV Line:
 - Voltage: 132 kV
 - Length: 10400 m
 - Loss fraction at STC: 0.50%
 - Wire section: 185 mm²
 - Material: Aluminum

- MV/LV Transformation stage:
 - Number of transformation centers: 4
 - Number of transformers per center: 5
 - Vector group: Dy11y11
 - Voltages: 20 kV/660 V
 - Nominal apparent power at STC: 49261 kVA (12315 kVA/center)
 - Iron loss: 0.20%
 - Copper loss: 0.80% at STC
 - Transformer manufacturer: 'Power Electronics'
 - Model: 'Twin Skid Compact'

- HV/MV Transformation stage:
 - Number of transformation centers: 1
 - Voltages: 132/20 kV
 - Nominal apparent power at STC: 52000 kVA
 - Iron loss: 0.10%
 - Copper loss: 0.22% at STC

4. **Conclusions:**

Simulating on PVSyst software provided optimizations subjected to different constraints that made possible the design of a realistic solar power plant model.

As for the components used, bifacial panels make a difference between the ones that do not take advantage of the albedo effect, given that the latter are only able to transform irradiance directly originating in the sun and not the one reflecting on the ground. Moreover, single-axis trackers are competitive in prices and higher efficiency as they follow the motion of the sun.

Having obtained an NPV of €13,778,419.15 and an IRR of 9% with a WACC of 5%, the project is fit to be given green light, recovering the €31,152,040 initial investment by the 15th year with an expected 30-year lifetime period.

ESTUDIO DE VIABILIDAD DE PLANTA SOLAR FOTOVOLTAICA DE GRAN POTENCIA

Autor: Córdoba Ocaña, Miguel

Directora: Alonso Alonso, Consolación

Entidad Colaboradora: ICAI-Universidad Pontificia de Comillas

RESUMEN DEL PROYECTO:

1. Introducción:

El efecto fotovoltaico es un fenómeno físico que consiste en la irradiación solar sobre una superficie con el fin de generar electricidad.

A día de hoy, contamos con tecnología desarrollada para aprovechar este fenómeno y producir energía en un mercado competitivo con huella de carbono neutra. Esta tecnología es el núcleo principal de este Proyecto. A saber, los paneles solares generadores que forman la central eléctrica.

El Proyecto, con una capacidad de 50.00 MWp, se ubica en un radio de 11.4 km de la subestación eléctrica de Riega (red de transporte, 132 kV) en la provincia de Ciudad Real en España.

2. Desarrollo:

Los pasos principales seguidos para llevar a cabo este proyecto han sido:

- a) Análisis de diferentes datos de radiación solar en bases solares (Meteonorm)
- b) Análisis de pendientes en el terreno (Google Earth)
- c) Selección de la cantidad adecuada de hectáreas (Google Earth)
- d) Selección de la subestación eléctrica para la inyección de energía (Mapa Eléctrico R.E.E. 2018)
- e) Simulación energética para selección de componentes (programa PVSyst).
- f) Selección de los inversores adecuados
- g) Selección de los seguidores apropiados
- h) Cálculos presupuestarios
- i) Análisis de rentabilidad
- j) Planos de proyecto

3. Resultados:

Los resultados de análisis y simulación han sido los siguientes:

- Potencia pico instalada (Pp): 50.00 MW
- Potencia nominal de los inversores (Pn): 48.00 MWa
- Relación (Pp/Pn): 1.042

- Pérdida por sobrecarga: 0.0%
- Potencia nominal del panel solar fotovoltaico bifacial unitario: 530 W
- Producción anual de energía: 99.9 GWh/año
- Producción específica anual: 1998 kWh/kWp/año
- *Performance ratio*: 85.27%
- Descripción general del diseño:
 - Número de módulos: 94338 (3494 cadenas de 27 módulos cada una)
 - Área del módulo: 241132 m²
 - Área de cobertizo: 242525 m²
 - Área física total: 65.6 hectáreas
 - Número de seguidores: 295
 - Número de inversores: 10
 - Número de etapas de transformación: 2

Donde los modelos de cada elemento de la planta son los siguientes:

- Paneles: LONGI SOLAR 'LR5-72 HBD 530 MBD M Bifacial', 530 Wp, 35 V, silicio monocristalino (Si-mono)
- Inversores: SIEMENS 'SINACON PV4800', 4800 kW, 962-1500 V, 50/60 Hz
- Seguidores: IDEEMATEC 'SafeTrack H4plus bifacial' (a un eje)

Elementos del sistema de inyección a la red

- Líneas BT (por inversor):
 - Tensión: 660 V
 - Longitud: 9.2 m x 10 inversores
 - Fracción de pérdidas en STC: 0.08%
 - Sección de cable: 4000 mm²
 - Material: Aluminio

- Líneas MT:
 - Tensión: 20 kV
 - Longitud: 1000 m x 4 líneas
 - Fracción de pérdidas en STC: 0.32%
 - Sección de cable: 300 mm²
 - Material: Aluminio
 - Recubrimiento: XLPE
 - Fabricante: 'Eland Cables'
 - Modelo: 'YMz1Krvasdlwd-AL 12/20kV Cable'

- Línea AT:
 - Tensión: 132 kV
 - Longitud: 10400 m
 - Fracción de pérdidas en STC: 0.50%
 - Sección de cable: 185 mm²
 - Material: Aluminum

- Etapa de transformación MT/BT:
 - Número de centros de transformación: 4
 - Número de transformadores por centro: 5
 - Grupo de conexión: Dy11y11
 - Tensiones: 20 kV/660 V
 - Potencia aparente nominal en STC: 49261 kVA (12315 kVA/center)
 - Pérdidas en el hierro: 0.20%
 - Pérdidas en el cobre: 0.80% en STC
 - Fabricante de transformador: 'Power Electronics'
 - Modelo: 'Twin Skid Compact'

- Etapa de transformación AT/MT
 - Número de centros de transformación: 1
 - Tensiones: 132/20 kV
 - Potencia aparente nominal en STC: 52000 kVA
 - Pérdidas en el hierro: 0.10%
 - Pérdidas en el cobre: 0.22% en STC

4. Conclusiones:

La simulación en el software PVSyst proporciona optimizaciones sujetas a diferentes restricciones que permiten el diseño de un modelo de planta de energía solar realista.

En cuanto a los componentes utilizados, los paneles bifaciales marcan la diferencia con los que no aprovechan el efecto albedo, ya que estos últimos sólo son capaces de transformar la irradiación que se origina directamente en el sol y no la que se refleja en el suelo. Además, los seguidores de un solo eje plantean competitividad entre precio y mayor eficiencia ya que siguen el movimiento del sol.

Habiendo obtenido un VAN de 13,778,419.15 € y un TIR del 9% con un WACC del 5%, el proyecto resulta ser rentable, recuperando la inversión inicial de 31.152.040 € el año 15, considerando un periodo de 30 años de vida útil.

TABLE OF DOCUMENTS

- DOCUMENT I. PROJECT NARRATIVE..... 11
- DOCUMENT II. PROJECT PLANS..... 112
- DOCUMENT III. CASH FLOW TABLES..... 116

DOCUMENT I. **PROJECT NARRATIVE**

INDEX

0. Project objectives.....	17
1. Introduction.....	19
2. A brief history of solar technology.....	21
3. State of the art in solar energy.....	22
4. Photovoltaic solar power plant general description.....	23
5. Photovoltaic solar technologies.....	24
5.1. The photovoltaic effect.....	24
5.2. Photovoltaic materials.....	24
5.3. The photovoltaic panel.....	25
5.3.1. General aspects.....	25
5.3.2. Specific aspects.....	26
5.3.3. Further aspects of interest.....	28
5.3.3.1. Bifaciality.....	28
5.3.3.2. Mismatch loss.....	29
5.3.3.3. LID loss factor.....	29
5.3.3.4. Module quality.....	29
5.3.3.5. IAM losses.....	29
5.3.3.6. Backtracking.....	29
6. Inverter.....	30
7. Panel structures.....	31
7.1. Fixed-tilt structures.....	31
7.2. Single-axis tracker.....	31
7.3. Dual-axis tracker.....	32
8. Grid interconnections.....	33
9. Project-TECHNICAL LAYER.....	34
9.1. Initial constraints.....	34
9.2. Site.....	34
9.2.1. Location, surroundings, and ground properties.....	34
9.2.2. Physical data.....	35
9.3. PVSyst simulation.....	41
9.3.1. Component selection.....	41
9.3.1.1. Panels and array.....	42
9.3.1.2. Inverters.....	44
9.3.1.3. Trackers.....	46
9.3.1.4. Electrical grid-injection system design overview.....	47
9.3.1.4.1. MV lines design.....	47
9.3.1.4.2. MV/LV transformers design.....	48

9.3.1.4.3. Connection of elements.....	48
9.3.1.4.4. Electrical design results.....	49
9.3.2. Plant global overview.....	50
9.4. Savings on CO ₂	53
9.5. Conclusions.....	54
10. Project-ECONOMIC LAYER.....	55
10.1. Initial Investment.....	56
10.2. Yearly amortization.....	57
10.3. Income.....	58
10.4. Profitability analysis.....	61
10.5. Conclusions.....	63
11. Bibliography.....	64
ATTACHMENTS.....	66

LIST OF FIGURES

Figure 1: Sun fusion reaction.....	19
Figure 2: 2030 Agenda Sustainable Development Goals.....	19
Figure 3: Installed capacity for renewable technologies.....	22
Figure 4: The photovoltaic effect.....	25
Figure 5: I-V curve for a photovoltaic cell.....	25
Figure 6: Composition of the I-V curve.....	26
Figure 7: Solar cell equivalent circuit.....	27
Figure 8: I-V curve modifications due to irradiance variations.....	28
Figure 9: I-V curve modifications due to temperature variations.....	28
Figure 10: Bifaciality principles.....	28
Figure 11: IAM-incidence angle curve.....	29
Figure 12: Connection of strings to the inverters' DC ports.....	30
Figure 13: Fixed-tilt structure.....	31
Figure 14: Single-axis tracker.....	31
Figure 15: Dual-axis tracker.....	32
Figure 16: Simplified block diagram for the plant.....	33
Figure 17: Solar plant location, height: 26.68 km.....	35
Figure 18: Monthly global and diffuse radiations (kWh/m ²).....	35
Figure 19: Monthly sunshine graph.....	36
Figure 20: Daily global radiation (kWh/m ²).....	36
Figure 21: Monthly temperature-estimation boxplot diagram.....	37
Figure 22: Maximum and minimum daily temperature graph.....	37
Figure 23: In blue: Precipitation mm per month. In red: Days with precipitation per month.....	38
Figure 24: Monthly GHI comparison histogram for Meteonorm and NASA databases. 40	40
Figure 25: Yearly GHI comparison histogram for Meteonorm and NASA databases... 40	40
Figure 26: I-V curves of a PV module for different irradiance values at 25°C..... 43	43
Figure 27: I-V curves of a PV module for different temperature values with 1000 W/m ² irradiance..... 43	43
Figure 28: Efficiency-Input Power curve for the inverter..... 45	45
Figure 29: Apparent Power-Temperature curve for the inverter..... 45	45
Figure 30: Perspective of the PV-field and surrounding shading scene..... 50	50
Figure 31: Shadings Diagram..... 50	50
Figure 32: Plant's Sankey Diagram for year 1..... 51	51
Figure 33: Yearly energy production graph..... 53	53
Figure 34: CO ₂ saved in a 30-year lifetime..... 53	53
Figure 35: Yearly average price evolution curve for Spain..... 58	58
Figure 36: Yearly electricity price boxplot diagram..... 59	59
Figure 37: Yearly average price expectations histogram..... 61	61
Figure 38: Yearly expected operating income histogram..... 61	61
Figure 39: Yearly cash flow expectations histogram..... 63	63

LIST OF TABLES

Table 1: Monthly solar data I.....	38
Table 2: Monthly solar data II.....	39
Table 3: Monthly solar data III.....	41
Table 4: Decision table for module selection.....	42
Table 5: Decision table for inverter selection.....	44
Table 6: Decision table for tracker selection.....	46
Table 7: Decision table for pitch selection.....	46
Table 8: Maximum allowed currents (A) in steady state and AC for underground insulated unipolar cables with 18/30 kV maximum grid voltages.....	47
Table 9: Selection table for MV cables.....	47
Table 10: Selection table for MV/LV transformers.....	48
Table 11: Yearly energy production table.....	53
Table 12: Investment costs table.....	56
Table 13: Length of the lines table.....	56
Table 14: Initial investment calculation table.....	57
Table 15: Amortization table I.....	57
Table 16: Amortization table II.....	57
Table 17: Values for the average price per year in <i>Figure 35</i>	58
Table 18: Yearly expected average price and income.....	60
Table 19: Yearly cash flow table.....	62
Table 20: Profitability parameters.....	63

LIST OF FORMULAS

Formula 1: Einstein's formula for the theory of general relativity.....	19
Formula 2: Photon energy formula.....	24
Formula 3: Form factor definition.....	26
Formula 4: Cell efficiency definition.....	26
Formula 5: NPV formula.....	55
Formula 6: Amortization formula.....	55

PROJECT NARRATIVE

0. Project objectives:

The Project at hand's main aim is the design of a photovoltaic solar power plant whose peak power reaches 50.00 MW, located in the province of Ciudad Real in Spain. The substation to which it will be connected is the 132 kV substation in Riega.

The main steps that were taken in order to carry out the project have been:

1) Location selection according to the following issues:

- Appropriate solar irradiance
- Ground characteristics (local slopes less than 10%)
- Accessibility (near a road or highway)
- Possibility of energy injection in the transmission grid (as much as 20 km distance between the power plant and the nearest substation)
- Civil work possibilities according to current environmental legislation (natural spaces protected under law)

Therefore, the selected location has the following coordinates:

- Longitude: -2.865427°
- Latitude: 39.161530°

These angular coordinates were chosen according to the constraints stated above. The main characteristics of this location are its easy accessibility to the A-43 highway, its low local slopes and the high solar irradiance over the ground. Furthermore, no protected spaces are being put in jeopardy and the high-voltage substation of Riega is at an 11.4 km distance from the connection points in the power plant to the energy injection system.

2) Solar irradiance and software simulation for energy production:

METEONORM was the base used to provide the solar data to the PVSyst software and PVGIS was used to provide the form of the terrain in which the plant lies.

Moreover, several simulation scenarios were carried out in order to choose the main components, in other words, the panels, the trackers and the inverters.

3) Main elements in the solar generators' design:

- Solar generating technology (panel model)
- Tracking technology:
 - Fixed-tilt structure
 - Single-axis tracker
 - Dual-axis tracker

- Inverter model

4) Electrical design overview:

- Medium and high voltages selection according to the plant's output voltage and the substation's grid voltage.
- Connection system:
 - Lines length
 - Wire section
 - Material for cables

5) Budgetary/Profitability analysis:

It mainly encompasses the investment's profitability after analyzing all of the data provided by PVSyst software.

1. Introduction:

Sun-generated energy is the outcome of a fusion reaction in such a star. This process involves hydrogen atoms that, when put together at the required conditions, form helium atoms delivering a high amount of energy (*see Figure 1*) quantified in Einstein’s famous formula for the theory of general relativity. (*see Formula 1*)




Figure 1: Sun fusion reaction (Source: [2])

$$E = mc^2$$

Formula 1: Einstein’s formula for the theory of general relativity (Source: [10])

Where:

- E is the energy delivered in the fusion reaction [J]
- m is the mass difference [kg]
- c is the light speed *in vacuo* whose value is 299 792 458 [ms⁻¹]

Given the climate expectations stated in the 2030 agenda, formally called “Sustainable Development Goals” (*see Figure 2*), solar technology has become ever more attractive to western governments, especially Europeans, due to its neutral carbon footprint and government-financing prospects over other energy sources.



Figure 2: 2030 Agenda Sustainable Development Goals (Source: [4])

In this case, the Project's sustainable development goals would be:

- Goal 7: Affordable and clean energy (solar energy is profitable and has a neutral carbon footprint)
- Goal 9: Industry, Innovation, and Infrastructure (investigation and development of new solar panels allow the enhancement of their efficiency. Therefore, an easier and more attractive industrial application is possible)
- Goal 11: Sustainable cities and communities (The application of this technology would make communities emit 0 CO₂ tons)
- Goal 12: Responsible consumption and production (As solar technology is characterized by a neutral carbon footprint, the environment is believed not to be harmed)
- Goal 13: Climate action (United Nations bets on renewable energy, in this case solar, in order to protect the environment)

2. A brief history of solar technology:

Solar technology has always revolved around the photovoltaic effect.

NOTE: The following historical facts are a direct translation from Spanish to English by the author of this Project. They are quoted from *Slide 2, Source [5]*.

“The photovoltaic effect was first recognized by French physicist Alexandre-Edmond Becquerel in 1839. His studies about the solar spectrum, magnetism, electricity, and optics are photovoltaic energy’s main pillar.

In 1883, the American inventor Charles Fritts built the first solar cell with [no more than] 1% efficiency.

In 1905, Albert Einstein managed to explain the photovoltaic effect and was awarded the Physics Nobel Prize in 1921 for his services to *the theory of Physics, especially his discovery of the photovoltaic effect laws*.

The silicon cell used nowadays originated in the American inventor Russell Ohl’s patent. It was built in 1940 and patented in 1946.

The modern times for the silicon cell began in 1954 in Bell Telephone Labs. By accident, while experimenting with semiconductors, it was found that silicon with minimum impurities was highly light-sensitive.

In 1958, the USA launched the *Vanguard I* satellite to space with the first photovoltaic system being part of it and operated with success. [The photovoltaic system] was constituted of 6 panels mounted on an outer sphere-shaped area. Every panel contained 18 polycrystalline silicon cells. Its [whole] output power oscillated between 50-100 W for 6 years.”

3. State of the art in solar energy:

“Power generation from solar PV in 2020 is estimated to have increased by a record 156 TWh, marking 23% growth from 2019. Solar PV accounted for 3.1% of global electricity generation, and it remains the third-largest renewable electricity technology behind hydropower and onshore wind after overtaking bioenergy in 2019.” (Source: [18])

As for solar energy in Spain, it accounted for 4,854 MW in 2015, and 9,071 MW in 2020. With regards to the objectives for the future, it is intended to increase the installed power by reaching 21,713 MW in 2025, and 39,181 MW in 2030. In 2021, solar energy accounted for 8.1% of the energetic mix. It is intended to increase that number to 24.1% by the end of the year 2030 as stated in the 2030 Agenda. (Source: [19])

Moreover, the implications of increasing solar energy installed power along with other renewable sources would be a lesser energetic dependence from abroad as it is planned to progressively shut down all generation plants that do not harness renewable energy. In the case of Spain, the fuel is imported in this instance. Consequently, if following this reasoning, solar PV technology is a perfect substitute for an energetic self-supply.

The following figure shows the installed capacity of renewable technologies from 2015 to 2030 (with estimations beginning after 2020).




Figure 3: Installed capacity for renewable technologies (Source: [19])

4. Photovoltaic solar power plant general description:

The part of a PV solar plant designed to harness solar energy is the array. This array is composed of strings. The strings are formed by solar modules containing solar cells. These solar cells are the unitary basic element of the generators manufactured with semiconductors.

The power is DC-generated (*direct current*). Nevertheless, it must be injected into an AC (*alternating current*) power grid. In order to achieve this, the inverter modifies the voltage from DC to AC. Once the output energy is AC, it must be injected into the grid.

The injection requires 3 different cables. These are LV (*low voltage*), MV (*medium voltage*), and HV (*high voltage*). The LV cables go from each inverter to the MV/LV transformation stage. On the MV side, the cables go to the HV/HV transformation stage, where the HV lines drive power to the nearest substation.

Furthermore, the trackers also play an important role in any solar plant. They are the structures that hold the plant's panels. They can be fixed-tilt, single-axis, or dual-axis. The two last follow the motion of the sun, hence presenting attractiveness to buyers.

5. Photovoltaic solar technologies:

5.1. The photovoltaic effect:

The photovoltaic effect consists of direct solar irradiance over a surface made of semiconductor materials that transform this solar energy into electricity.

In order to produce electricity, electrons must be freed from the element they belong to by absorbing photonic energy. Namely, if a light photon meets an atom, one of its electrons in the atom's outer shell will change its energy level. Therefore, if the photon has enough energy, it can make the electron move to the atom's highest energy level and free it with kinetic energy. The necessary energy is always a discrete value that is quantified in *Formula 2*.

$$E = \frac{hc}{\lambda}$$

Formula 2: Photon energy formula (Source: [5])

Where:

- E is the energy of one photon [J]
- h is Planck's constant with a value of $6.62607015 \times 10^{-34}$ [m²kgs⁻¹]
- c is the light speed *in vacuo* whose value is 299 792 458 [ms⁻¹]
- λ is the photon's wavelength [m]

5.2. Photovoltaic materials:

Any element is clustered into 3 categories:

- conductors
- insulators
- semiconductors

Conductors are characterized by their low impedance, whereas insulators present a high one. However, semiconductors are in the middle and can work both as insulators and conductors depending on the physical conditions they work under. Furthermore, one property of interest is the existence of 2 subgroups each:

- P-type: The semiconductor has an electron-vacancy excess
- N-type: The semiconductor has an excess of electrons

This property, as stated above, is of special interest given that putting one of each conductor type together, while photon-irradiated, makes electrons from the N-type go to the P-type, thus creating a voltage drop as shown in the following figure.




Figure 4: The photovoltaic effect (Source [5])

This is exactly the solar panels' working principle.

5.3. The photovoltaic panel:

5.3.1. General aspects:

A photovoltaic panel is a set of module strings that when connected in series and/or in parallel to form what is called an array, generate a DC voltage drop. This voltage drop is caused by the photovoltaic effect as stated in all of the above.

A photovoltaic cell is the union of several P-N semiconductor materials so that the photovoltaic effect takes place. As seen in the previous part, the current is DC-generated. Nevertheless, it is not constant. This fact is due to a recombination of the electron carriers. Consequently, the I-V curve has the shape shown in *Figure 5*.




Figure 5: I-V curve for a photovoltaic cell (Source: [2])

Where:

- I_{sc} represents the current when voltage equals 0V (short-circuit equivalent)
- V_{oc} represents the output voltage when current equals 0A (open-loop equivalent. 0.6V is a reasonable value for silicon cells).
- P_{max} represents the maximum power that a cell can deliver.

P_{max} can also be calculated with V_{oc} and I_{sc} and through this, the Form Factor (FF) is defined as shown in *Formula 3*.

$$FF = \frac{P_{max}}{V_{oc} * I_{sc}}$$

Formula 3: Form factor definition (Source: [6])

Moreover, efficiency can also be defined with the available variables as shown in *Formula 4*.

$$\eta = \frac{I_{sc} * V_{oc} * FF}{A * G}$$

Formula 4: Cell efficiency definition (Source: [6])

Where:

- I_{sc} , V_{oc} and FF have already been defined
- G is the irradiance per area unit in standard conditions (measurement: $G=1000 \text{ W/m}^2$)
- A is the area of the panel [m^2]

5.3.2. Specific aspects:




Figure 6: Composition of the I-V curve (Source: [6])




Figure 7: Solar cell equivalent circuit (Source: [6])

As shown in Figure 6 and Figure 7, and as it has already been explained, the current in a solar cell has two components:

- Lighting current due to the direct impact of photons over the semiconductor (I_L or I_{foton})
- Dark current due to the recombination of electron carriers (I_D)




Figure 8: I-V curve modifications due to irradiance variations (Source: [6])




Figure 9: I-V curve modifications due to temperature variations (Source: [6])

As shown in *Figure 7* and *Figure 8*, weather conditions play an important role in energy production. The lower the temperature outside and the higher the solar irradiance, the higher the output power. The higher the temperature outside and the lower the solar irradiance, the lower the output power.

5.3.3. Further aspects of interest:

5.3.3.1. Bifaciality:

Bifacial panels are designed to work on both of their sides. This feature helps the panel absorb not only direct horizontal irradiance as classic ones do but absorb a considerable amount of diffuse and reflected irradiance due to the albedo effect.

As for the panel selection in this Project, they will be bifacial for the reason stated above.




Figure 10: Bifaciality principles (Source: [2])

5.3.3.2. Mismatch losses:

Solar cells, as previously seen, have a maximum current they can withstand. Therefore, when building cell strings and connecting the cells in series, just one current will be the only one in the equivalent circuit. Namely, if two cells connected in series have a different I_{max} , the lowest one is the string determinative maximum current.

A manufacturer builds a panel connecting its cells in series or parallel depending on the main properties he or she wishes to equip it with.

5.3.3.3. LID loss factor:

LID (Light Induced Degradation) losses are due to the degradation of crystalline silicon modules in the first operating hours with respect to the manufacturing flash test STC (standard conditions) values.

5.3.3.4. Module quality:

Deviation of the average effective module efficiency with respect to manufacturer specifications.

5.3.3.5. IAM losses:

Losses due to the panels' inclination.




Figure 11: IAM-incidence angle curve (Source: PVSyst)

5.3.3.6. Backtracking:

Solar backtracking is a tracking control program that aims to minimize panel-on-panel shading, thus minimizing possible production losses.

6. The inverter:

As has already been mentioned, the panel generates a DC voltage. Yet, the power must be injected into an AC grid. In order to do so, the inverter converts the DC voltage into a three-phase AC voltage.

As for the model to be chosen, its nominal power must be similar to the plant's peak power to avoid overload losses due to undersizing or a P_p/P_n ratio smaller than 1 due to oversizing. As this Project consists of a high-power plant, more than one inverter is needed. All of them will be connected in parallel. The connecting structure will be similar to the one below in *Figure 12*.




Figure 12: Connection of strings to the inverters' DC ports (Source: [8])

7. Panel support structures:

7.1. Fixed-tilt structure:

This structure does not follow the motion of the sun. As a consequence, there are times during the day when the energy generated is excessively low due to considerable shadings.

WINTOP




Figure 13: Fixed-tilt structure (Source: [22])

7.2. Single-axis tracker:

A single-axis tracker is the simplest tracking system and the most profitable given it follows the motion of the sun on just one axis (North-South), hence maximizing energy production and optimizing the power plant's efficiency. Furthermore, its price and energy-optimizing ease make it the most market-competitive among others.



Figure 14: Single-axis tracker (Source: [1])

7.3. Dual-axis tracker:

A dual-axis tracker has a North-South and an East-West axis which both enable it not only to follow the sun but correct the modules' orientation to absorb the maximum amount of solar irradiance perpendicularly to its surface. This feature makes this tracker the most competitive in terms of efficiency. Nevertheless, its cost is much higher than others, thus not being the most profitable one.



Figure 15: Dual-axis tracker (Source: [1])

8. Grid interconnections:

Once the solar energy has gone through the inverter it needs to be injected into a power system. Namely, a substation. The inverter has an LV output voltage which needs to be transformed into an appropriate grid voltage. The following transformations are the ones to be undergone in this process:

-LV to MV

-MV to HV (substation voltage)

The number of transformers will be the one that withstands the power flow. All of them will be connected in parallel.

Moreover, with respect to the lines, HV lines must be considerably longer than MV lines given that the lower the voltage, the bigger the losses. Consequently, most of the interconnection system needs to be HV. As for the line elements, they can be made from copper or aluminum. Copper is more conductive, yet heavier than aluminum. For this reason, aluminum is more attractive to manufacturers due to its cheaper transportation costs.




Figure 16: Simplified block diagram for the plant (Source: [8])- From left to right:
GENERATION-INVERSION-TRANSFORMATION-INJECTION

9. Project - TECHNICAL LAYER:

All of the above is meant to provide insight into how the project at hand should be tackled. From this part on, project results will be exposed as well as the steps taken to deliver them.

9.1. Initial constraints for site selection:

- Peak power: 30-50 MWp (50 MWp is the value of the peak power)
- Area: Maximum 2 hectares/MWp
- Local slopes: Maximum 10%
- Proximity to a substation: Maximum 20 km radius
- The site should be out of any protected area
- Easy accessibility: There should be roads nearby. Otherwise, transportation and civil work costs might increase.
- Solar irradiation should be considerable. Namely, GHI (*Global Horizontal Irradiance*) values must be as high as possible. To that effect, a site in the province of Ciudad Real is advisable.

9.2. Site:

9.2.1. Location, surroundings, and ground properties:

Considering the constraints above, the location of the site has the following coordinates also stated in the introduction of this document:

- Longitude: -2.865427°
- Latitude: 39.161530°

The area is 65 hectares approximately (approximately 1.3 hectares/MWp) with less than 4% local slopes and is next to the A-43 highway without trespassing any protected area.

Tomelloso is the nearest town in the province of Ciudad Real and the nearest interconnection point is the 132 kV substation of Riega (11.4 km radius).



Figure 17: Solar plant location, height: 26.68 km (Source: Google Earth Pro)

9.2.2. Physical data:

The following figures and table show the physical data of interest for the Project.

- **Monthly global and diffuse radiations graph:**




Figure 18: Monthly global and diffuse radiations (kWh/m²) (Source: Meteonorm)

- **Monthly sunshine graph:**




Figure 19: Monthly sunshine graph (Source: Meeonorm)

- **Daily global radiation graph:**




Figure 20: Daily global radiation (kWh/m^2) (Source: Meeonorm)

- **Monthly temperature-estimation boxplot diagram:**




Figure 21: Monthly temperature-estimation boxplot diagram (Source: Meteonorm)

- **Maximum and minimum daily temperature graph:**




Figure 22: Maximum and minimum daily temperature graph (Source: Meteonorm)

- **Monthly precipitation graphs:**




Figure 23: In blue: Precipitation mm per month. In red: Days with precipitation per month (Source: Meteonorm)

- **Monthly solar data**

	GHI (kWh/m ²)	DHI (kWh/m ²)	Bn (kWh/m ²)	Ta (°C)	Td (°C)	W (m/s)
January	65	27	101	5.7	1.9	2.9
February	85	35	109	7.3	1.7	3.3
March	137	52	156	10.5	3.4	3.4
April	172	66	174	13.4	5.9	3.2
May	204	73	203	17.8	7.7	2.9
June	221	69	229	23.6	9.3	3
July	240	61	269	26.9	10.2	3
August	214	44	264	26.3	11	2.9
September	159	47	195	21.4	10.5	2.7
October	114	44	140	16.1	9.2	2.5
November	72	29	107	9.4	4.7	2.8
December	58	24	95	6.2	2.9	2.7
Year	1741	571	2042	15.4	6.5	2.9

Table 1: Monthly solar data I (Source: Meteonorm)

Where:

- GHI is the Global Horizontal Irradiance
- DHI is the Diffuse Horizontal Irradiance
- Bn is the Direct Horizontal Irradiance
- Ta is the ambient temperature
- Td is the dewpoint temperature
- W is the wind speed

Among the six types of data, from left to right, in the “Year” row, the first three are a sum of their respective columns, while the three last are an arithmetic average.

	GHI (kWh/m ²)	Ta (°C)	W (m/s)
January	70.27	4.5	2.59
February	89.58	6.05	2.74
March	139.12	9.15	2.83
April	167.33	11.81	2.8
May	204.09	16.49	2.57
June	223.03	22.28	2.47
July	234.09	26.01	2.48
August	204.3	25.77	2.44
September	153.51	20.89	2.42
October	108.95	14.98	2.54
November	72.87	8.87	2.65
December	61.66	5.65	2.62
Year	1729	14.37	2.59

Table 2: Monthly solar data II (Source: NASA, Own elaboration)

Among the three types of data, from left to right, in the “Year” row, the first column is a sum of all its data, while the two last are an arithmetic average.

As to what base is more accurate to introduce the data in PVSyst software, Meteonorm may well be more appropriate given that the site is in Europe and Meteonorm’s developer is European as well. Nevertheless, to select the most appropriate base, we must analyze the GHI data:

- Meteonorm: 1741 kWh/m²
- NASA: 1729 kWh/m²

The values slightly differ between themselves, therefore being of no consequence the fact of selecting one base or the other. Nonetheless, since Meteonorm is the most optimistic one, we will choose it according to this criterion.

The following graphs offer a visual approach of the GHI.




Figure 24: Monthly GHI comparison histogram for Meteornorm and NASA databases (Source: Own elaboration)




Figure 25: Yearly GHI comparison histogram for Meteornorm and NASA databases (Source: Own elaboration)

	GHI (kWh/m ²)	DHI (kWh/m ²)	Ta (°C)	W (m/s)
January	64.7	27.4	5.1	2.8
February	83.9	32.9	6.7	3.29
March	136.1	49.8	10.3	3.4
April	171.8	57.6	13.2	3.2
May	204.6	71.4	18	2.91
June	220.7	66.6	23.8	3
July	238.1	62.2	27.8	3
August	212.3	51.9	27.1	2.89
September	158.6	46.8	21.4	2.7
October	113.8	43	16.2	2.5
November	71.8	28.1	8.9	2.79
December	57.3	27.3	5.6	2.69
Year	1734	565	15.3	2.93

Table 3: Monthly solar data III (Source: Meteonorm from PVSyst, Own elaboration)

9.3. PVSyst simulation:

PVSyst is a solar energy software designed to simulate photovoltaic systems. It has been developed by the University of Geneva for this purpose. In the project at hand, it enables the user to simulate different elements, such as panels and inverters, whose main data are uploaded to the program database, in different scenarios. To that effect, multiple combinations of elements allow the most accurate optimization.

Moreover, system losses and tracker dimensioning can also be analyzed to obtain optimal results.

In order to carry out the simulation, a concise analysis of solar irradiance data in different databases has to be previously conducted to select the most appropriate base. PVSyst software is able to connect to these databases and extract the necessary information. However, the data from a PVSyst extraction, if compared to the data extracted directly by the user from the same base, might well differ although within an acceptable range due to differences in the period taken.

9.3.1. Component selection:

One of the main aims of this project is to design a solar plant with the maximum peak power possible. In this case 50.00 MWp. As a consequence, all the components (panels, trackers, inverters, and grid connection systems) must be selected in order to cover the nominal and peak powers.

Variations on the P_p/P_n ratio and the E-W pitch shall be done to choose the most appropriate components to comply with the statements above.

9.3.1.1. Panels and array:

All the modules will be bifacial to take advantage of the energy produced thanks to the albedo effect. Moreover, reaching the maximum possible peak power was set as an aim for this project.

The following table shows multiple options considered:

Model	Power (W)	Number of modules (per string)	Number of strings	Assigned plant's peak power (MW)	Required area (m ²)
LR5-72 HBD 530 M Bifacial (Longi Solar)	530	27	3494	50	241132
LR5-72 HBD 525 M Bifacial (Longi Solar)	525	27	3527	50	243479
LR5-72 HBD 525 M Bifacial (Longi Solar)	520	27	3561	50	245825

Table 4: Decision table for module selection (Source: Own elaboration)

Given that the first option requires the less amount of area, the model ‘LR5-72 HBD 530 M Bifacial (Longi Solar)’ will be the one selected. What follows is the categorization of this panel and array models:

- Panels:

- Model: LR5-72 HBD 530 M Bifacial
- Manufacturer: Longi Solar
- Nominal power: 530 W (at STC)
- Technology: monocrystalline silicon

- Reference conditions: $G_{ref} = 1000 \text{ W/m}^2$
- Reference Temperature: $T_{ref} = 25^\circ\text{C}$

- Short-circuit current: $I_{sc} = 13.710 \text{ A}$
- Open-circuit voltage: $V_{oc} = 49.20 \text{ V}$
- Maximum power output: $P_{max} = 531.1 \text{ W}$; with $V_{mpp} = 41.35 \text{ V}$ and $I_{mpp} = 12.820 \text{ A}$; $FF = 0.7874$

- Number of cells in series: 72 x 2 (in parallel as cells are bifacial)
- Cell area: 165.1 cm²
- One Module Length: 2256 mm
- One Module Width: 1133 mm
- One Module Thickness: 35.0 mm
- One Module Area: 2.556 m²
- One Module Weight: 32.30 kg




Figure 26: I-V curves of a PV module for different irradiance values at 25°C
(Source: PVSyst)




Figure 27: I-V curves of a PV module for different temperature values with 1000 W/m² irradiance (Source: PVSyst)

- Array:

- Modules in series per string: 27
- Number of strings: 3494
- Total number of modules: 94338
- Module area: 241132 m²

- Nominal power: 49999 kW (at STC)

- Overload loss: 0.0%
- Module efficiency loss: -3.0%
- Module mismatch loss: 2.0%
- Strings voltage mismatch loss: 0.1%
- LID loss factor: 1.5%
- Soiling loss factor: 2.0%
- IAM losses: 1.03%

- $I_{mpp} (STC) = 45708 \text{ A}$
- $V_{mpp} (60^{\circ}\text{C}) = 962 \text{ V}$
- $V_{mpp} (20^{\circ}\text{C}) = 1119 \text{ V}$

- $V_{oc} (-10^{\circ}\text{C}) = 1458 \text{ V}$
- $I_{sc} (STC) = 47903 \text{ A}$

9.3.1.2. Inverters:

In order to drive all the energy produced by the panels to the electrical injection system, the inverters need to have a nominal power that withstands 50 MW_p. One around 48 MW is reasonable as the inversion stage is neither oversized nor undersized. The following table shows the options considered.

Model	Power (kW)	Number of MPPT's (half an inverter)	Inverter loss during operation (%)	P _p /P _n ratio
SIEMENS Sinacon PV4800	4800	20	1.20%	1.042
WSTECH GmbH APS4800-PV-4-660-5	4800	20	1.20%	1.042
WSTECH GmbH APS4360-PV-4-600-5	4360	22	1.31%	1.043

Table 5: Decision table for inverter selection (Source: Own elaboration)

Considering a ratio of around 1.04 (48 MW nominal power with 50 MW peak power), the options for the inverter selection above met the requirements. ‘WSTECH GmbH APS4360-PV-4-600-5’ can automatically be discarded as there is a need for more inverters and more losses are present during the operation than in the other two cases. The final decision was to select ‘SIEMENS Sinacon PV4800’ as fewer operation losses exist, and fewer inverters are needed. Yet, ‘WSTECH GmbH APS4800-PV-4-660-5’ could have been selected instead for the exact same reasons since the parameters evaluated are the same in both cases.

What follows is the categorization of the inverter selected:

- Number of inverters: 10

- Model: Sinacon PV4800
- Manufacturer: Siemens

- Minimum $V_{mpp} = 962 \text{ V}$ (input side – DC)
- Maximum $V_{mpp} = 1500 \text{ V}$ (input side – DC)

- If we compare these voltage values with the ones in the array, we can certainly state that the inverter is appropriately designed to withstand the array's voltage.
- Nominal input power: 4836 kW
- Maximum PV power: 9600 kW (DC- input)
- Grid voltage: 660 V (AC-output)
- Nominal AC output power: 4800 kVA
- Maximum efficiency: 98.92%
- Width: 3503 mm
- Depth: 1142 mm
- Height: 3734 mm
- Weight: 3900 kg




Figure 28: Efficiency-Input Power curve for the inverter (Source: PVSyst)




Figure 29: Apparent Power-Temperature curve for the inverter (Source: PVSyst)

As it happens with an increasing temperature in the panels, the output power decreases in the inverter as well.

9.3.1.3. Trackers:

Two tracker-model options were considered:

- SOLTEC “SF8 SINGLE AXIS TRACKER” (4-6 strings/tracker)
- IDEEMATEC ‘SafeTrack H4plus bifacial’ (up to 360 modules/tracker)

	Maximum capacity	strings	modules	Number of trackers
SOLTEC	6 strings/tracker	3494		583
IDEEMATEC	360 modules/tracker		94338	263

Table 6: Decision table for tracker selection (Source: Own elaboration)

In light of the results in Table 6, IDEEMATEC is more profitable than SOLTEC as fewer trackers are required. However, when running simulations, 263 IDEEMATEC trackers did not cover the minimum required area for our plant. Therefore, the number of trackers had to be increased to 295 in order to meet this requirement.

Furthermore, the E-W pitch had also to be taken into account. In order to select it in an interval between 10 and 12 meters, the following selection table was elaborated:

E-W pitch (m)	Energy delivered (GWh)	Performance ratio (%)	GCR (%)	Near shadings losses (%)
10	95.2	83.20%	44.20%	1.81%
11	98.9	85.20%	40.20%	1.75%
12	99.9	85.32%	36.80%	1.69%

Table 7: Decision table for pitch selection (Source: Own elaboration)

In light of these last results, the greater the pitch, the bigger the energy delivered to the grid, since GCR (*Ground Coverage Ratio*) and near shading losses decrease. Therefore, a 12-meter pitch is the most appropriate option even though this might require a larger amount of area.

Having chosen the previous features, the trackers’ characteristics are the following:

- Sensitive area:
 - Shed area: 242525 m²
 - Required area: 241132 m²
 - Table area: 822.12 m²
 - Length: 186 m
 - Width: 4.42 m
- Tracking parameters:

- Model: SafeTrack H4plus bifacial (single-axis tracker)
- Manufacturer: Ideematec
- Number of trackers: 295
- Pitch E-W: 12 m
- Backtracking activated
- Rotating limits: $\pm 55^\circ$

9.3.1.4. Electrical grid-injection system design overview:

9.3.1.4.1. MV lines design:

Sección (mm ²)	EPR		XLPE		HEPR	
	Cu	Al	Cu	Al	Cu	Al
25	125	96	130	100	135	105
35	145	115	155	120	160	125
50	175	135	180	140	190	145
70	215	165	225	170	235	180
95	255	200	265	205	280	215
120	290	225	300	235	320	245
150	325	255	340	260	360	275
185	370	285	380	295	405	315
240	425	335	440	345	470	365
300	480	375	490	390	530	410
400	540	430	560	445	600	470

Table 8: Maximum allowed currents (A) in steady state and AC for underground insulated unipolar cables with 18/30 kV maximum grid voltages (Source: [21])

First and foremost, when designing high voltage lines, the parameter to consider is the maximum current through it without taking into account voltage drops. These are relevant in lower voltage levels.

The following table shows some options considered. The criterion followed for this selection is mainly economic, since building a line tends to be expensive. Hence, the minimum number of lines with the minimum wire section is the most appropriate for designing the MV system. Furthermore, the material used not only for MV lines but also for all the others will be aluminum as it is lighter than copper despite being less conductive.

Number of lines	Minimum wire section (mm ²)	Current (A)
1	1200	1422
2	700	711
3	400	474
4	300	356

Table 9: Selection table for MV cables (Source: Own elaboration)

Options 1 and 2 must be discarded as their minimum section does not comply with Table 8. Moreover, option 3 cannot be implemented as the maximum current is greater than the maximum allowed values.

Therefore, the most suitable option is 4 MV lines, 300 mm² wire section each. The insulation will be XLPE-type (*Cross-Linked Polyethylene*).

The manufacturer and model will be: ‘Eland Cables’, ‘YMz1Krvasd1wd-AL 12/20kV Cable’.

9.3.1.4.2. MV/LV transformers design:

Two options were considered to design the MV transformers. The following table shows them:

	MV Skid Compact	Twin Skid Compact
Minimum power at 40°C (kVA)	1525	3050
Maximum power at 40°C (kVA)	4390	8780
Minimum power at 50°C (kVA)	1415	2830
Maximum power at 50°C (kVA)	4075	8150
Required apparent power (kVA)	49261	49261
Minimum number of transformers for every option	33	17
	12	6
	35	18
	13	7

Table 10: Selection table for MV/LV transformers (Source: Own elaboration)

The ‘Twin Skid Compact’ model requires fewer transformers than its counterpart. However, in order to choose it is necessary to consider the least favorable case. Namely, at least 18 transformers.

Since the power flow should be as uniform as possible and all the transformers need to withstand a limited power, considering that we have 4 MV lines, thus requiring 4 transformation centers, 20 MV/LV transformers are needed.

9.3.1.4.3. Connection of elements:

- Number of strings: 3494
- Number of inverters: 10

For every inverter, 349 strings must be connected to them. Among these 10 inverters, 4 will host 350 strings instead of 349.

All the inverters, as their output voltage is the same (660 V at STC), will be connected to a single bar that will be connected to 4 MV/LV transformation centers composed of 5 transformers each.

On the MV side, the 4 lines previously designed will go to a connection bar to a HV/MV transformation center. A line will go from the HV side to the substation for energy injection.

9.3.1.4.4. Electrical design results:

- LV lines (per inverter):
 - Voltage: 660 V
 - Length: 9.2 m x 10 inverters
 - Loss fraction at STC: 0.08%
 - Wire section: 4000 mm²
 - Material: Aluminum

- MV Lines:
 - Voltage: 20 kV
 - Length: 1000 m x 4 lines
 - Loss fraction at STC: 0.32%
 - Wire section: 300 mm²
 - Material: Aluminum
 - Covering: XLPE
 - Manufacturer: 'Eland Cables'
 - Model: 'YMz1Krvasdlwd-AL 12/20kV Cable'

- HV Line:
 - Voltage: 132 kV
 - Length: 10400 m
 - Loss fraction at STC: 0.50%
 - Wire section: 185 mm²
 - Material: Aluminum

- MV/LV Transformation stage:
 - Number of transformation centers: 4
 - Number of transformers per center: 5
 - Vector group: Dy11y11
 - Voltages: 20 kV/660 V
 - Nominal apparent power at STC: 49261 kVA (12315 kVA/center)
 - Iron loss: 0.20%
 - Copper loss: 0.80% at STC
 - Transformer manufacturer: 'Power Electronics'
 - Model: 'Twin Skid Compact'

- HV/MV Transformation stage:
 - Number of transformation centers: 1
 - Voltages: 132/20 kV
 - Nominal apparent power at STC: 52000 kVA

- Iron loss: 0.10%
- Copper loss: 0.22% at STC

9.3.2. Plant global overview:




Figure 30: Perspective of the PV-field and surrounding shading scene
(Source: PVSyst)

The solar plant's physical dimensions are 186 m in width and 3528 m in length which makes a total area of 65.6 hectares.




Figure 31: Shadings Diagram (Source: PVSyst)

Almost no shadings are visible given that the terrain has low local slopes. Moreover, we can appreciate the sun is higher in the middle of the year than at the beginning and the end of it.




Figure 32: Plant's Sankey Diagram for year 1 (Source: PVSyst)

For year 1, the results shown below are the ones that best summarize the plant's production and efficiency which will decrease each year.

- Energy produced: 99.9 GWh
- Specific production: 1998 kWh/kWp
- Performance ratio: 85.27%

The following table shows the previous results for year 1 and an estimation for the next 29 years. The first 4 years are the results of a simulation while the rest is an estimation for the following years through the Excel program. Furthermore, the last data were compared to a simulation for year 30 and the error resulted to be between 2.0% and 2.6% depending on the variable, making our estimations reliable and acceptable (*criterion*: acceptable if the error is less than 5.0%)

Year	Total energy production (GWh)
1	99.9
2	99.5
3	99.0
4	98.6
5	98.2
6	97.7
7	97.3
8	96.8
9	96.4
10	95.9
11	95.5
12	95.1
13	94.6
14	94.2
15	93.8
16	93.3
17	92.9
18	92.4
19	92.0
20	91.6
21	91.1
22	90.7
23	90.2
24	89.8
25	89.4
26	88.9
27	88.5
28	88.0
29	87.6
30	87.2

Table 11: Yearly energy production table (Source: Own elaboration)




Figure 33: Yearly energy production histogram (Source: Own elaboration)

9.4. Savings on CO₂:




Figure 34: CO₂ saved in a 30-year lifetime (Source: PVSyst)

As the graph above shows, when doing the initial investment, 100,000 tCO₂ are emitted. It is, nonetheless, after the 3rd functioning year that there is a positive net CO₂ saving balance, reaching 650,000 tCO₂ in the 30th year.

9.5. Conclusions:

Bifacial panels present a significantly higher amount of absorbed irradiance than conventional ones. Absorbed irradiance on the rear side makes up 51.3% of the global horizontal irradiation value. Nevertheless, efficiency at STC is only around 21%. This means most of the energy is transformed into heat. However, if compared to the best panels' efficiency, 26%, it is an acceptable value (*Source: [16]*).

10. Project – ECONOMIC LAYER:

This part consists of evaluating the profitability or non-profitability of the project. For this, the NPV (*Net Present Value*) indicator, if it is greater than 0 it will mean the project is profitable, however, if this indicator is a negative value, the project should not see the light given that in all likelihood losing money is inevitable.

$$NPV = -I_o + \sum_{i=1}^n \frac{CF_i}{(1+k)^i}$$

Formula 5: NPV formula (Source: [13])

Where:

- I_o is the initial investment
- CF_i is the cash flow for the i th year
- k is the WACC (*Weighted Average Cost of Capital*)
- n is the number of years

Another way to evaluate the profitability of a project is through its IRR (*Internal Rate of Return*). If the IRR is greater than the WACC, the project will be profitable. On the contrary, if it is less than the WACC, it should not see the light.

Moreover, before calculating the NPV, calculations of the amortization A of the investment for the cash flows are necessary. The following formula is useful to estimate it.

$$A = k * \frac{(1+k)^n}{(1+k)^n - 1} * I_o$$

Formula 6: Amortization formula (Source: [13])

Where:

- k is the WACC (*Weighted Average Cost of Capital*)
- n is the project's lifetime
- I_o is the initial investment

10.1. Initial investment:

The initial investment comprehends the purchase of the modules, trackers, and transformation centers (with the inverters as a part of them), as well as the price of the lines, the interconnection, development, and EPC (*Engineering, Procurement and Construction*) costs.

The following table shows the cost of the elements above.

Costs	USD/Wp	EUR/km
Modules	0.26	
Trackers	0.1198	
Transformation centers and inverters	0.04	
Lines		120,000
Interconnection		
Development		
EPC	0.2567	

Table 12: Investment costs table (Source: Own elaboration)

Where:

- The peak power is 50.00 MWp
- \$1 is equivalent to €0.84 (*average 2021: Source: [17]*)

	LV	MV	HV
Number of lines	10	4	1
Unitary length (km)	0.0092	1	10.4
Length (km)	0.092	4	10.4

Table 13: Length of the lines table (Source: Own elaboration)

NOTE: For the lines, the cost is per distance unit and for every 3 electrical phases

The following table shows the calculation of the initial investment I_0 .

Costs	Total amount (EUR)
Modules	10,920,000.00
Trackers	5,031,600.00
Transformation centers and inverters	1,680,000.00
Lines	1,739,040.00
TOTAL AMOUNT MAIN ELEMENTS	19,370,640.00
Interconnection	400,000.00
Development	600,000.00
EPC	10,781,400.00
INITIAL INVESTMENT	31,152,040.00

Table 14: Calculation of the initial investment table (Source: Own elaboration)

10.2. Yearly amortizations:

Given an initial investment of €31,152,040, the yearly amortizations are calculated with *Formula 6*. Using a WACC of 5% and a 30-year lifetime period, the results are the ones that follow:

WACC	Lifetime period	Amortization (EUR)
5%	30	2,026,484.91

Table 15: Amortization table I (Source: Own elaboration)

Amortization years	Final Amortization payment (EUR)
15.37245103	754,766.38

Table 16: Amortization table II (Source: Own elaboration)

Considering the results above, the amortization period will be 15 years with €2,026,484.91 and a 16th year when it will be €754,766.38.

10.3. Income:




Figure 35: Yearly average price evolution curve for Spain (Source: [14])

Year	Average Price (EUR/MWh)
2007	42.19
2008	64.43
2009	36.96
2010	37.01
2011	49.93
2012	47.23
2013	44.26
2014	42.13
2015	50.32
2016	39.67
2017	52.24
2018	57.29
2019	47.68
2020	33.96
2021	111.93

Table 17: Values for the average price per year in Figure 35 (Source: Own elaboration)




Figure 36: Yearly electricity price boxplot diagram (Source: Own elaboration)

The previous boxplot highlights that the price in 2021 is an outlier. This is due to a lack of primary resources, uncontrolled inflation, and a plan of invasion of Ukraine by the Russian Federation that is currently ongoing, all of which made gas prices skyrocket, therefore making European electricity prices extremely high as most of Europe is dependent on Russian gas. Not to mention that this primary resource is the one that matches the final price in the electricity bills given that it fuels combined cycle plants.

Furthermore, in 2020, all the coal plants were closed in Spain, being a contributing factor to the rise in prices.

As the electricity price in 2021 is an outlier because of an extremely exceptional geopolitical situation, we will estimate our yearly price for year 1 with the average of the prices from 2007 to 2020 with a 1% increase every year as shown respectively in the following table and histograms.

Year	Average Price (EUR/MWh)	Yearly income (EUR)
1	46.09	4,604,676.43
2	46.55	4,632,101.68
3	47.02	4,654,913.03
4	47.49	4,682,466.36
5	47.96	4,710,105.26
6	48.44	4,732,984.28
7	48.93	4,760,742.72
8	49.42	4,783,641.26
9	49.91	4,811,512.89
10	50.41	4,834,422.48
11	50.92	4,862,400.63
12	51.42	4,890,454.90
13	51.94	4,913,390.15
14	52.46	4,941,540.87
15	52.98	4,969,763.26
16	53.51	4,992,704.70
17	54.05	5,021,012.75
18	54.59	5,043,928.89
19	55.13	5,072,314.63
20	55.69	5,100,763.70
21	56.24	5,123,650.32
22	56.80	5,152,165.03
23	57.37	5,175,000.43
24	57.95	5,203,571.94
25	58.53	5,232,197.38
26	59.11	5,254,963.88
27	59.70	5,283,632.69
28	60.30	5,306,319.47
29	60.90	5,335,021.84
30	61.51	5,363,767.62

Table 18: Yearly expected average price and income (Source: Own elaboration)




Figure 37: Yearly average price expectations histogram (Source: Own elaboration)




Figure 38: Yearly expected operating income histogram (Source: Own elaboration)

10.4. Profitability analysis:

With the Operating Income, O&M (*Operation and Maintenance*) costs ($\$12/kW$ estimation), the Generation Tax (7% on income), the amortizations, the Corporation Tax (25% on profits), the initial investment, and the Operating Funds Requirement Investment (7% on income), the yearly cash flows are respectively calculated and represented in the following table and histogram.

NOTE: An inflation rate of 1.50% was considered for the calculation of the O&M costs.

Year	Cash flows (EUR)
0	-31,152,040.00
1	3,018,055.69
2	3,029,595.03
3	3,038,154.11
4	3,049,602.44
5	3,061,016.85
6	3,069,355.51
7	3,080,665.73
8	3,088,834.74
9	3,100,031.37
10	3,108,019.92
11	3,119,093.19
12	3,130,116.98
13	3,137,829.88
14	3,148,715.30
15	3,159,544.00
16	2,849,026.07
17	2,671,008.96
18	2,678,193.69
19	2,688,702.67
20	2,699,141.84
21	2,705,979.38
22	2,716,235.70
23	2,722,813.69
24	2,732,874.83
25	2,742,851.79
26	2,749,032.49
27	2,758,795.31
28	2,764,681.00
29	2,782,691.74
30	2,792,254.20

Table 19: Yearly cash flows table (Source: Own elaboration)




Figure 39: Yearly cash flow expectations histogram (Source: Own elaboration)

The results were:

NPV	€13,778,419.15
IRR	9%
WACC	5%
Investment recovery year	15

Table 20: Profitability parameters (Source: Own elaboration)

10.5. Conclusions:

In light of the profitability results, the investment will be recovered by the 15th year, which is half of its lifetime, with a positive NPV and an IRR of 9% having previously considered a WACC of 5%. Therefore, the project is profitable, and can be given green light.

NOTE: The attachment XI shows a Gantt diagram for the different stages of the plant from the Basic Engineering to Starting Process.

11. Bibliography:

- [1] Breton, I. “Diseño de la planta solar fotovoltaica del Puerto de Santa María (Cádiz) utilizando como herramienta computacional el programa PVsyst”
- [2] Allue, JM. “Proyecto de ejecución de una planta solar fotovoltaica de 2,9963 MWp para generación de energía eléctrica en el municipio de Brazatortas (provincia de Ciudad Real)”
- [3] United Nations, Department of Economic and Social Affairs, Sustainable Development, “Transforming our world: the 2030 Agenda for Sustainable Development” (online) Link:
<https://sdgs.un.org/2030agenda>
- [4] Ciudades Sostenibles, “An Urban Perspective on Gender and Diversity for the 2030 Agenda” (online) Link:
<https://blogs.iadb.org/ciudades-sostenibles/en/an-urban-perspective-on-gender-and-diversity-for-the-2030-agenda/>
- [5]Trasperecias U.E., "Tema 3. El Efecto Fotovoltaico"
- [6]Trasperecias U.E., "Tema 4. La célula solar y el panel fotovoltaico de silicio cristalino"
- [7]Trasperecias U.E., "Tema 5. Tecnologías Fotovoltaicas"
- [8]Trasperecias U.E., "Tema 8. Seguidores, Inversores y Transformadores"
- [9]Trasperecias ICAI, "Aplicaciones de electrónica de potencia. Tema 2.1: Convertidores CC-CA trifásicos. Pablo García González. Julio 2020"
- [10]Arno Smets, Klaus Jäger, Olindo Isabella, René van Smaaij, Miro Zeman, "Solar Energy. The Physics and Engineering of Photovoltaic Conversion Technologies and Systems"
- [11] FSEC Energy Research Center, University of Central Florida, “Cells, Modules and Arrays” (online) Link:
<https://energyresearch.ucf.edu/consumer/solar-technologies/solar-electricity-basics/cells-modules-panels-and-arrays/>
- [12] R.E.E., “Mapa del sistema eléctrico ibérico 2018” (online) Link:
https://www.ree.es/sites/default/files/01_ACTIVIDADES/Documentos/Mapas-de-red/mapa_transporte_iberico_2018.pdf
- [13] Trasperecias ICAI, "Análisis de viabilidad económica de proyectos. José Ignacio Linares Hurtado. Curso 2021-22"
- [14] OMIE, “Day-ahead minimum, average and maximum price” (online) Link:
<https://www.omie.es/es/market-results/interannual/daily-market/daily-prices?scope=interannual>

[15] Andy Walker, Eric Lockhart, Jal Desai, Kristen Ardani, Geoff Klise, Olga Lavrova, Tom Tansy, Jessie Deot, Bob Fox, and Anil Pochiraju, "Model of Operation-and-Maintenance Costs for Photovoltaic Systems" (online) Link:
<https://www.nrel.gov/docs/fy20osti/74840.pdf>

[16] Mark Mills, PragerU, "What's wrong with wind and solar?" (online) Link:
<https://www.prageru.com/video/whats-wrong-with-wind-and-solar>

[17] Eurostat, "Taux d'échange de l'euro/écu – données annuelles" (online) Link:
<https://appsso.eurostat.ec.europa.eu/nui/submitViewTableAction.do>

[18] Solar PV, "Policy deadlines led to a PV deployment boom in 2020, but more effort is needed to reach 2030 Net Zero levels" (online) Link:
<https://www.iea.org/reports/solar-pv>

[19] Vicepresidencia Tercera del Gobierno, Ministerio de la Transición Ecológica y el Reto Demográfico, "Plan nacional integrado de energía y clima 2021-2030" (online) Link:
https://www.miteco.gob.es/images/es/pnieccompleto_tcm30-508410.pdf

[20] PVYSyst Photovoltaic Software (online) Link:
<https://www.pvsyst.com/fr/>

[21] Real Decreto 223/2008, de 15 de febrero (online) Link:
<https://www.boe.es/boe/dias/2008/03/19/pdfs/A16436-16554.pdf>

[22] Wintop (online) Link:
<http://m.solar-energy-company.com/solar-flat-roof-mounting/fixe-d-tilt-solar-flat-roof-racking-of.html>

ATTACHMENTS

LIST OF ATTACHMENTS

ATTACHMENT I. Simulation report.....	68
ATTACHMENT II. Module datasheet.....	79
ATTACHMENT III. Inverter datasheet.....	82
ATTACHMENT IV. Tracker datasheet.....	87
ATTACHMENT V. MV cable datasheet.....	90
ATTACHMENT VI. MV/LV transformer datasheet.....	94
ATTACHMENT VII. Software list.....	97
ATTACHMENT VIII. Matlab algorithm for <i>Figure 36</i> elaboration.....	99
ATTACHMENT IX. Official PVSyst output tabs.....	101
ATTACHMENT X. Natural spaces currently protected under Spanish law.....	108
ATTACHMENT XI. Gantt diagram.....	110
ATTACHMENT XII. Acronym table.....	112

ATTACHMENT I. Simulation report



Version 7.2.17

PVsyst - Simulation report

Grid-Connected System

Project: FinalDegreeProject

Variant: Nueva variante de simulación_ELE

Trackers single array, with backtracking

System power: 50.00 MWp

LocationTFG - Spain

Author

Miguel Córdoba (Spain)



PVsyst V7.2.17
VC4, Simulation date:
12/08/22 12:06
with v7.2.17

Project: FinalDegreeProject
Variant: Nueva variante de simulación_ELE

Miguel Córdoba (Spain)

Project summary

Geographical Site	Situation	Project settings
LocationTFG Spain	Latitude 39.16 °N Longitude -2.87 °W Altitude 699 m Time zone UTC	Albedo 0.20
Meteo data		
LocationTFG Meteonorm 8.0 (1996-2017), Sat=100% - Sintético		

System summary

Grid-Connected System	Trackers single array, with backtracking
Simulation for year no 1	
PV Field Orientation	Near Shadings
Orientation Tracking plane, horizontal N-S axis Axis azimuth 0 °	Tracking algorithm Astronomic calculation Backtracking activated
System information	Inverters
PV Array	
Nb. of modules 94338 units Pnom total 50.00 MWp	Nb. of units 10 units Pnom total 48.00 MWac Pnom ratio 1.042
User's needs Unlimited load (grid)	

Results summary

Produced Energy	100 GWh/year	Specific production	1998 kWh/kWp/year	Perf. Ratio PR	85.27 %
-----------------	--------------	---------------------	-------------------	----------------	---------

Table of contents

Project and results summary	2
General parameters, PV Array Characteristics, System losses	3
Near shading definition - Iso-shadings diagram	6
Main results	7
Loss diagram	8
Special graphs	9
CO ₂ Emission Balance	10



PVsyst V7.2.17
 VC4, Simulation date:
 12/08/22 12:06
 with v7.2.17

Project: FinalDegreeProject
 Variant: Nueva variante de simulación_ELE

Miguel Córdoba (Spain)

General parameters

Grid-Connected System		Trackers single array, with backtracking	
PV Field Orientation		Tracking algorithm	
Orientation		Astronomic calculation	
Tracking plane, horizontal N-S axis		Backtracking activated	
Axis azimuth	0 °		
Models used		Backtracking array	
Transposition	Perez	Nb. of trackers	295 units
Diffuse	Perez, Meteorom	Single array	
Circumsolar	separate	Sizes	
		Tracker Spacing	12.0 m
		Collector width	4.42 m
		Ground Cov. Ratio (GCR)	36.8 %
		Phi min / max.	-/+ 55.0 °
		Backtracking strategy	
		Phi limits	+/- 68.3 °
		Backtracking pitch	12.0 m
		Backtracking width	4.42 m
Horizon		Near Shadings	
Free Horizon		Linear shadings	
Bifacial system		User's needs	
Model	2D Calculation	Unlimited load (grid)	
	unlimited trackers		
Bifacial model geometry		Bifacial model definitions	
Tracker Spacing	12.00 m	Ground albedo	0.15
Tracker width	4.42 m	Bifaciality factor	70 %
GCR	36.8 %	Rear shading factor	7.0 %
Axis height above ground	2.30 m	Rear mismatch loss	10.0 %
		Shed transparent fraction	0.0 %

PV Array Characteristics

PV module		Inverter	
Manufacturer	Generic	Manufacturer	Generic
Model	LR5-72 HBD 530 M Bifacial	Model	Sinacon PV4800
	(Original PVsyst database)		(Original PVsyst database)
Unit Nom. Power	530 Wp	Unit Nom. Power	4800 kWac
Number of PV modules	94338 units	Number of inverters	20 * MPPT 50% 10 units
Nominal (STC)	50.00 MWp	Total power	48000 kWac
Modules	3494 Strings x 27 In series	Operating voltage	962-1500 V
At operating cond. (50°C)		Pnom ratio (DC:AC)	1.04
Pmpp	45.83 MWp		
U mpp	1003 V		
I mpp	45708 A		
Total PV power		Total inverter power	
Nominal (STC)	49999 kWp	Total power	48000 kWac
Total	94338 modules	Number of inverters	10 units
Module area	241132 m²	Pnom ratio	1.04
Cell area	224256 m²		



PVsyst V7.2.17
 VC4, Simulation date:
 12/08/22 12:06
 with v7.2.17

Project: FinalDegreeProject
 Variant: Nueva variante de simulación_ELE

Miguel Córdoba (Spain)

Array losses

Array Soiling Losses		Thermal Loss factor		DC wiring losses				
Loss Fraction	2.0 %	Module temperature according to irradiance		Global array res.	0.24 mΩ			
		Uc (const)	29.0 W/m²K	Loss Fraction	1.0 % at STC			
		Uv (wind)	0.0 W/m²K/m/s					
LID - Light Induced Degradation		Module Quality Loss		Module mismatch losses				
Loss Fraction	1.5 %	Loss Fraction	-0.3 %	Loss Fraction	2.0 % at MPP			
Strings Mismatch loss		Module average degradation						
Loss Fraction	0.1 %	Year no	1					
		Loss factor	0.46 %/year					
		Mismatch due to degradation						
		Imp RMS dispersion	0 %/year					
		Vmp RMS dispersion	0 %/year					
IAM loss factor								
Incidence effect (IAM): User defined profile								
0°	25°	45°	60°	65°	70°	75°	80°	90°
1.000	1.000	0.995	0.962	0.936	0.903	0.851	0.754	0.000

System losses

Auxiliaries loss	
Proportional to Power	3.0 W/kW
0.0 kW from Power thresh.	

AC wiring losses

Inv. output line up to MV transfo		HV line up to Injection	
Inverter voltage	660 Vac tri	HV line voltage	132 kV
Loss Fraction	0.08 % at STC	Wires	Alu 3 x 185 mm²
Inverter: Sinacon PV4800		Length	10400 m
Wire section (10 Inv.)	Alu 10 x 3 x 4000 mm²	Loss Fraction	0.50 % at STC
Average wires length	9 m		
MV line up to HV Transfo			
MV Voltage	20 kV		
Average each inverter			
Wires	Alu 3 x 300 mm²		
Length	1000 m		
Loss Fraction	0.32 % at STC		

AC losses in transformers

MV transfo	
Medium voltage	20 kV
Operating losses at STC	
Nominal power at STC	49261 kVA
Iron loss (24/24 Connexion)	24.63 kW/Inv.
Loss Fraction	0.20 % at STC
Coils equivalent resistance	3 x 0.28 mΩ/inv.
Loss Fraction	0.80 % at STC



PVsyst V7.2.17
VC4, Simulation date:
12/08/22 12:06
with v7.2.17

Project: FinalDegreeProject

Variant: Nueva variante de simulación_ELE

Miguel Córdoba (Spain)

AC losses in transformers



HV transfo		Operating losses at STC	
Grid voltage	132 kV	Nominal power at STC	49261 kVA
Transformer from Datasheets		Iron loss (24/24 Connexion)	50.00 kW
Nominal power	52000 kVA	Loss Fraction	0.10 % at STC
Iron loss	50.00 kVA	Coils equivalent resistance	3 x 17.75 mΩ
Loss Fraction	0.10 % of PNom	Loss Fraction	0.22 % at STC
Copper loss	120.00 kVA		
Loss Fraction	0.23 % of PNom		



PVsyst V7.2.17
 VC4, Simulation date:
 12/08/22 12:06
 with v7.2.17

Project: FinalDegreeProject
 Variant: Nueva variante de simulación_ELE

Miguel Córdoba (Spain)





PVsyst V7.2.17
 VC4, Simulation date:
 12/08/22 12:06
 with v7.2.17

Project: FinalDegreeProject
 Variant: Nueva variante de simulación_ELE

Miguel Córdoba (Spain)

Main results

System Production


Produced Energy

100 GWh/year


Specific production
 Performance Ratio PR

1998 kWh/kWp/year
 85.27 %

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray GWh	E_Grid GWh	PR ratio
January	64.7	27.41	5.05	87.6	82.3	4.11	3.90	0.890
February	83.9	32.93	6.71	111.2	105.8	5.24	5.00	0.900
March	136.1	49.85	10.30	184.3	176.3	8.51	8.17	0.886
April	171.8	57.62	13.15	230.8	221.6	10.46	10.05	0.871
May	204.6	71.43	18.02	271.1	260.4	12.03	11.57	0.854
June	220.7	66.62	23.77	295.0	284.0	12.79	12.31	0.835
July	238.1	62.16	27.79	322.6	311.0	13.69	13.19	0.818
August	212.3	51.88	27.12	291.4	280.8	12.45	11.98	0.823
September	158.6	46.79	21.36	218.9	210.2	9.61	9.23	0.843
October	113.8	43.05	16.20	154.5	147.4	7.00	6.72	0.869
November	71.0	28.12	8.95	99.1	93.6	4.60	4.38	0.885
December	57.3	27.29	5.62	76.4	71.3	3.58	3.39	0.887
Year	1732.9	565.13	15.39	2342.9	2244.8	104.06	99.89	0.853

Legends


GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		



PVsyst V7.2.17
 VC4, Simulation date:
 12/08/22 12:06
 with v7.2.17

Project: FinalDegreeProject
 Variant: Nueva variante de simulación_ELE

Miguel Córdoba (Spain)






PVsyst V7.2.17
 VC4, Simulation date:
 12/08/22 12:06
 with v7.2.17

Project: FinalDegreeProject
 Variant: Nueva variante de simulación_ELE


Miguel Córdoba (Spain)

Special graphs

Daily Input/Output diagram



Distribución de potencia de salida del sistema





PVsyst V7.2.17
 VC4, Simulation date:
 12/08/22 12:06
 with v7.2.17

Project: FinalDegreeProject
 Variant: Nueva variante de simulación_ELE

Miguel Córdoba (Spain)

CO₂ Emission Balance

Total: 651599.2 tCO₂

Generated emissions

Total: 94665.94 tCO₂

Source: Detailed calculation from table below:

Replaced Emissions

Total: 860084.0 tCO₂

System production: 99893.62 MWh/yr

Grid Lifecycle Emissions: 287 gCO₂/kWh


Source: IEA List

Country: Spain

Lifetime: 30 years

Annual degradation: 1.0 %

Saved CO₂ Emission vs. Time



System Lifecycle Emissions Details

Item	LCE	Quantity	Subtotal [kgCO ₂]
Modules	1713 kgCO ₂ /kWp	49999 kWp	85634527
Supports	1.91 kgCO ₂ /kg	4716900 kg	9029515
Inverters	190 kgCO ₂ /units	10.00 units	1896

ATTACHMENT II. Module datasheet

Hi-MO 5

LR5-72HBD 530~550M

- Based on M10-182mm wafer, best choice for ultra-large power plants
- Advanced module technology delivers superior module efficiency
 - M10 Gallium-doped Wafer • Smart Soldering • 9-busbar Half-cut Cell
- Globally validated bifacial energy yield
- High module quality ensures long-term reliability

 12-year Warranty for Materials and Processing

 30-year Warranty for Extra Linear Power Output

Complete System and Product Certifications

IEC 61215, IEC 61730, UL 61730
ISO 9001:2015: ISO Quality Management System
ISO 14001: 2015: ISO Environment Management System
TS62941: Guideline for module design qualification and type approval
ISO 45001: 2018: Occupational Health and Safety

LONGI





Hi-MO 5

LR5-72HBD 530~550M


21.5% MAX MODULE EFFICIENCY	0~3% POWER TOLERANCE	<2% FIRST YEAR POWER DEGRADATION	0.45% YEAR 2-30 POWER DEGRADATION	HALF-CELL Lower operating temperature
--	-----------------------------------	--	--	---

Additional Value



Mechanical Parameters

Cell Orientation	144 (6×24)
Junction Box	IP68, three diodes
Output Cable	4mm ² , +400, -200mm/±1400mm length can be customized
Glass	Dual glass, 2.0+2.0mm heat strengthened glass
Frame	Anodized aluminum alloy frame
Weight	32.3kg
Dimension	2256×1133×35mm
Packaging	31pcs per pallet / 155pcs per 20' GP / 620pcs per 40' HC



Electrical Characteristics

Module Type	STC: AM1.5 1000W/m ² 25°C		LR5-72HBD-535M		LR5-72HBD-540M		LR5-72HBD-545M		LR5-72HBD-550M	
	STC	NOCT	STC	NOCT	STC	NOCT	STC	NOCT	STC	NOCT
Maximum Power (Pmax/W)	530	396.2	535	399.9	540	403.6	545	407.4	550	411.1
Open Circuit Voltage (Voc/V)	49.20	46.26	49.35	46.40	49.50	46.54	49.65	46.68	49.80	46.82
Short Circuit Current (Isc/A)	13.71	11.07	13.78	11.12	13.85	11.17	13.92	11.23	13.99	11.29
Voltage at Maximum Power (Vmp/V)	41.35	38.58	41.50	38.72	41.65	38.86	41.80	39.00	41.95	39.14
Current at Maximum Power (Imp/A)	12.82	10.27	12.90	10.33	12.97	10.39	13.04	10.45	13.12	10.51
Module Efficiency(%)	20.7		20.9		21.1		21.3		21.5	

Operating Parameters

Operational Temperature	-40°C ~ +85°C
Power Output Tolerance	0 ~ 3%
Voc and Isc Tolerance	±3%
Maximum System Voltage	DC1500V (IEC/UL)
Maximum Series Fuse Rating	30A
Nominal Operating Cell Temperature	45±2°C
Protection Class	Class II
Bifaciality	70±5%
Fire Rating	UL type 29 IEC Class C

Mechanical Loading

Front Side Maximum Static Loading	5400Pa
Rear Side Maximum Static Loading	2400Pa
Hailstone Test	25mm Hailstone at the speed of 23m/s

Temperature Ratings (STC)

Temperature Coefficient of Isc	+0.050%/°C
Temperature Coefficient of Voc	-0.265%/°C
Temperature Coefficient of Pmax	-0.340%/°C



No.8369 Shangyuan Road, Xi'an Economic And Technological Development Zone, Xi'an, Shaanxi, China.
Web: en.longi-solar.com

Specifications included in this datasheet are subject to change without notice. LONGI reserves the right of final interpretation. (20211101V14)

ATTACHMENT III. Inverter datasheet

SIEMENS
Ingenuity for life




SINACON PV
Photovoltaic Central Inverter

Technical data 01/2020

The SINACON PV inverter is used in medium and large utility-scale photovoltaic power plants to achieve high efficiency. It is equipped with 3-level IGBT modules for input voltages of up to DC 1,500 V to maximize energy efficiency. The integrated DC and AC distribution makes the SINACON PV inverter cost efficient. Standardized interfaces for easy plug and play reduce engineering hours.

- Designed for harsh environments
- IP65 without humidity limits
- Liquid cooling (-40°C ... +60°C possible)
- Late power derating over 40°C
- Extreme high quality standards



The SINACON PV inverter is part of the MV-Inverter Station with the transformer and RMU (Ring Main Unit) in the eBoP solution (electrical Balance of Plant).

SINACON PV series | Technical data


Storage, transportation and operation				
Temperature	-40 °C ... +60 °C			
Relative humidity	0% ... 100%			
Maximum altitude of installation site without derating	< 1,500 m above MSL			
Cooling				
Cooling method	Forced cooling by means of fans and liquid cooling			
Applicable standards and conformity				
BDEW (Germany)	BDEW Guideline, FGW TG3, TG4 and TG8			
IEC 61683 (efficiency)	IEC 61683: 1999			
IEC 62116 (anti islanding)	IEC 62116: 2014 (at 50 Hz)			
EMC Emission	IEC 61000-6-4: 2007 + A1: 2011			
EMC Immunity	IEC 61000-6-2: 2005			
Electrical Safety	IEC 62109-1: 2010, IEC 62109-2: 2011, IP65 according to IEC 60529: 1989			
Degree of protection: IP65 (cabinet only)	IEC 60529			
General data				
Control strategy	MPPT			
Efficiency (PV 5000)	(97.6 98.5 98.9 98.9 99.0 98.9 98.8 98.7)%	For (5 10 20 25 30 50 75 100)% power at 1,006 V _{DC} without self-consumption for cooling		
EU and CEC efficiency	98.8%	Without internal consumption		
Infeed starts from	260 W ... 2,500 W	Depending on cooling		
Standby loss	80 W ... 150 W	-		
Max. self-consumption for cooling	5,000 W	Without cabinet heating		
Mechanical data				
Mounting position	Vertical	-		
Type of mounting	Floor mounting	-		
				
Number of Power Units	1	2	3	4
SINACON PV series	PV1000 ... PV1250	PV2000 ... PV2500	PV3000 ... PV3750	PV4000 ... PV5000
Dimensions (without pallet, with heat exchanger); (W x H x D)	2,120 x 3,760 x 1,170 mm		3,690 x 3,760 x 1,170 mm	
Weight ¹⁾	< 1,600 kg	< 2,200 kg	< 3,300 kg	< 3,900 kg
Color	RAL 7035			
Input data (DC)				
Independent inputs	1 ... 2		Depending on configuration	
Nominal voltage	min. MPP voltage		-	
DC voltage (max. MPP)	1,500 V		Depending on application	
DC voltage (min. MPP)	802 V / 882 V (AC 550 V) 838 V / 922 V (AC 575 V) 875 V / 962 V (AC 600 V) 919 V / 1,010 V (AC 630 V) 962 V / 1,058 V (AC 660 V) 1,006 V / 1,107 V (AC 690 V)		For 100% / 110% nominal grid voltage	
DC current (max.)	1 ... 4 x 1,200 A		-	
Short-circuit current (max.)	6,4 kA / 7 kA		250 A / 315 A DC fuses	
Nominal power	1 ... 4 x 1,016 kW 1 ... 4 x 1,062 kW 1 ... 4 x 1,108 kW 1 ... 4 x 1,159 kW 1 ... 4 x 1,209 kW 1 ... 4 x 1,270 kW		-	
Capacitance to ground (max.)	2,000 µF		Per IT system	

¹⁾ The weight refers to a complete system without extra options.


Output data (AC)

Apparent power (max.) and nominal power	PV1000...PV4000 kVA (AC 550 V) PV1045...PV4180 kVA (AC 575 V) PV1090...PV4360 kVA (AC 600 V) PV1140...PV4560 kVA (AC 630 V) PV1200...PV4800 kVA (AC 660 V) PV1250...PV5000 kVA (AC 690 V)	With nominal grid voltage, $\cos \phi = 1$
Number of independent systems	1 ... 2	-
Grid voltage	550 ... 690 V ($\pm 10\%$ at $U_{n(AC)}$)	-
Nominal frequency	50 Hz / 60 Hz ($\pm 10\%$)	-
Output current (max.)	1 ... 4 x 1,050 A	-
Short-circuit current (max.)	50 kA	-
Power factor $\cos \phi$	-	Adjustable to local requirements
Harmonic distortion	< 3%	-

Measured values²⁾ without internal consumption for AC 600 V (PV4360)



Derating



²⁾ Measured by Fraunhofer ISE

SINACON PV series | Technical data

Order information – The order number consists of several digits depending on the configuration.

Description	1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	11.	12.	13.	14.	15.	16.		
SINACON PV inverter for medium voltage supply	6	S	P	1														
Number of power units																		
• 1 power unit					1													
• 2 power units					2													
• 3 power units					3													
• 4 power units					4													
Input connections (per power unit on plus and minus)																		
• 7 x M10 bolt and nut						0												
Initial current measurement at DC input																		
• Each + input measured							1											
Minimum operating ambient temperature																		
• Up to -10°C								0										
• Up to -25°C, with cabinet heating								1										
• Up to -40°C, with cabinet heating and insulation								2										
Applied standards																		
• IEC with external AC connection									E									
• UL with external AC connection									U									
Network-/optical fiber switch connection																		
• Singlemode unmanaged										S								
• Multimode unmanaged										M								
• RJ45										R								
Seismic design																		
• Without seismic design											0							
• With seismic design											1							
Frequency																		
• 50 Hz												5						
• 60 Hz												6						
Inverter output AC voltage																		
• 550 V (PV1000 ... PV4000)															4			
• 575 V (PV1045 ... PV4180)															5			
• 600 V (PV1090 ... PV4360)															6			
• 630 V (PV1140 ... PV4560)															7			
• 660 V (PV1200 ... PV4800)															8			
• 690 V (PV1250 ... PV5000)															9			
Grounding/Insulation monitoring																		
• Insulation monitoring internal																I		
• Negative-pole grounding without isolation monitoring																N		
Inverter options																		
• None																N		
• AC precharge																A		
Additional internal transformer																		
• 63 A fuse																2		
• Transformer with 8 kVA, AC 400 V																3		
• none																9		
Example:	6	S	P	1	4	0	1	-	0	E	S	0	5	-	6	N	N	3

Published by
Siemens AG

Smart Infrastructure
Distribution Systems
Mozartstrasse 31c
91052 Erlangen, Germany



Article No. SIDS-B10020-00-7600
HL 19125033 WS 01200.0
© Siemens 2020

For the U.S. published by
Siemens Industry Inc.

100 Technology Drive
Alpharetta, GA 30005
United States

Subject to changes and errors. The information given in this document only contains general descriptions and/or performance features which may not always specifically reflect those described, or which may undergo modification in the course of further development of the products. The requested performance features are binding only when they are expressly agreed upon in the concluded contract

ATTACHMENT IV. Tracker datasheet



IDEEMATEC is the leading developer...

...of single axis tracking systems, headquartered in Germany with more than 12 years of experience and over 2.2 GW of installed systems on 6 continents.

IDEEMATEC's innovative high-span safeTrack H4 tracker™ offers an outstanding design DNA. As first two-in-portrait tracker in the market, powered by its core patented drive technology, IDEEMATEC's solar tracker offers a superior safety and uptime level. Now available **safeTrack H4^{PLUS} bifacial tracker™** for an even higher yield at maximum reduced shading.

Established technology for challenging conditions – suited for sites with challenging soils, high winds, and irregular terrain, IDEEMATEC's safeTrack H4 trackers™ reduce the risk for Engineering, Procurement & Construction Companies by pro-

viding project developers and asset owners with the most value added over the entire lifetime of their power plant.

Highest Peak Power Ratio – the safeTrack H4™ flexible string configuration allows for a max. number of modules per tracker and requires only 1 Drive Unit for 360 Modules to provide support for up to 12x 1500-volt strings – **currently the market benchmark**. With only 0.5 pcs. SIGMA foundations per DC string, the high-span safeTrack H4™ reduces tracker installation costs by offering the least amount of posts at the lowest embedding depth.


THE DEFINITION OF 2P TRACKING

DISCONNECTED DRIVE



- 2.5 Hz natural frequency
- Zero torsion table
- Galloping excluded

ZERO STOW POSITION



- Up to 300 % less stress
- 360° wind protection
- Best in practice stow strategy

DYNAMIC ABSORBERS



- Damping ratio 15%
- 0° stow position safe & stable over entire length
- Dynamic stability in any position



THE LONGEST TRACKER IN THE MARKET

up to 180 meters | 360 modules




GENERAL MECHANICAL FEATURES

Tracking type	Horizontal single axis tracker – unlinked row
Typical tracker size	2 Portrait II 183 mtr. (max.)
Array height	2.20 m (7'22") Standard
H4^{PLUS} bifacial features	H4^{PLUS} – tracker height gain compensation
Tracking range	± 55°
Wind protection	Stow Position 0° / multi damping
Foundations	Sigma shape
Materials	Galvanized steel
Warranty	10 Years II Standard



▲ HIGHER YIELD
MORE RAIL DISTANCE
▼ LESS SHADING



EXTREMELY ADAPTABLE
TO ANY TERRAIN




ONLY 1 DRIVE UNIT
FOR 150 KWP

POWER AND CONTROL SYSTEM

Software	KoRoNa™ by IDEEMATEC
Solar tracking method	Astronomical algorithm II 3D adaptive backtracking
Communication	Full wired II redundant data transfer and control flow
Drive type	High accuracy slew gear – disconnected
Motor type	CE 400V 50Hz/ UL 480V 60Hz
Operating temperature range	-20°C up to +55°C
Warranty	5 Years II Standard

MODULES AND CONFIGURATION

2P configuration 1500 Volt	Modules Pcs.		Strings	Width	Length
6 Table	336	360	12	72 cell / 78 cell	174m / 186m
5 Table	280	300	10	4.0m / 4.4m	145m / 155m
4 Table	224	240	8		116m / 124m



SAFE AND STABLE
0° STOW POSITION

ATTACHMENT V. MV cables datasheet

**ELAND[®]
CABLES**

Click here for more information:
elandcables.com | [YMz1KrvasdIwd-AL 12/20kV Cable](#)

YMz1KrvasdIwd-AL 12/20kV Cable



Eland Product Group: B1E

APPLICATION

LSZH Medium Voltage cable with aluminium conductors offering a lightweight alternative to copper conductor alternatives. Suitable for use in conduit and for fixed, protected installation. For installations where fire, smoke emission and toxic fume create a potential risk to life and equipment.

CHARACTERISTICS

Voltage Rating U_o/U
12/20kV

Temperature Rating
Fixed: 0°C to +90°C

Maximum Conductor Short-Circuit Temp up to 5 sec: 250°C

Minimum Bending Radius

Single Core: 15 x overall diameter
Multi Core: 12 x overall diameter

CONSTRUCTION

Conductor
Class 2 Stranded Aluminium

Inner Semi-Conductive Layer
Semi-Conductive Material

Insulation
XLPE (Cross-Linked Polyethylene)

Outer Semi-Conductive Layer
Semi-Conductive Material

Screen
Copper wires and tape

Tape
Longitudinal and Radial Water Blocking

Outer Sheath
LSZH (Low Smoke Zero Halogen) UV Resistant

Core Identification
Multi Cores: ● Brown ● Black ● Grey

Sheath Colour
● Red

STANDARDS

Generally to HD 620-10J / NEN 3620
Fire Resistant to IEC/EN 60332-1-2, IEC/EN 60332-3-24 Cat.C

ISO/IEC 17025 LABORATORY TESTED

This product is subject to the Quality Assurance protocols of The Cable Lab[®], an ISO/IEC 17025 accredited cable testing laboratory. Testing includes vertical flame, conductor resistance, tensile & elongation, and dimensional consistency, verified to published standards and approved product drawings.



REGULATORY COMPLIANCE

This cable meets the requirements of the RoHS Directive 2011/65/EU. RoHS compliance has been tested and confirmed by The Cable Lab[®] as meeting the requirements of the BSI RoHS Trusted Kitemark[™].





DIMENSIONS

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL CROSS SECTIONAL AREA OF SCREEN mm ²	NOMINAL DIAMETER OVER CONDUCTOR mm	NOMINAL THICKNESS OF INSULATION mm	NOMINAL THICKNESS OF SEMI-CONDUCTIVE LAYER mm		NOMINAL THICKNESS OF SHEATH mm	NOMINAL OVERALL DIAMETER mm	NOMINAL WEIGHT kg/km
						Inner	Outer			
B1E20KV01050RD	1	50	25	8.10	4.50	0.50	0.40(fully bonded)	2.50	30	1100
B1E20KV01070RD	1	70	25	9.70	4.50	0.50	0.40(fully bonded)	2.50	31	1200
B1E20KV01095RD	1	95	25	11.40	4.50	0.50	0.40(fully bonded)	2.50	33	1300
B1E20KV01120RD	1	120	25	12.60	4.50	0.50	0.40(fully bonded)	2.50	34	1400
B1E20KV01150RD	1	150	25	14.10	4.50	0.50	0.40(fully bonded)	2.50	36	1500
B1E20KV01185RD	1	185	25	15.80	4.50	0.50	0.40(fully bonded)	2.50	37	1700
B1E20KV01240RD	1	240	25	18.10	4.50	0.50	0.40(fully bonded)	2.50	40	1900
B1E20KV01300RD	1	300	25	20.20	4.50	0.50	0.40(fully bonded)	2.50	42	2200
B1E20KV01400RD	1	400	50	23.00	4.50	0.50	0.40(fully bonded)	2.50	45	2750
B1E20KV01500RD	1	500	50	26.00	4.50	0.50	0.40(fully bonded)	2.50	48	3250
B1E20KV01630RD	1	630	50	30.10	4.50	0.50	0.40(fully bonded)	2.50	52	3750
B1E20KV03050RD	3	50	70	8.10	4.50	0.50	0.40(fully bonded)	3.20	60	3250
B1E20KV03070RD	3	70	70	9.70	4.50	0.50	0.40(fully bonded)	3.20	63	3700
B1E20KV03095RD	3	95	70	11.40	4.50	0.50	0.40(fully bonded)	3.20	67	4000
B1E20KV03120RD	3	120	70	12.60	4.50	0.50	0.40(fully bonded)	3.20	70	4500
B1E20KV03150RD	3	150	70	14.10	4.50	0.50	0.40(fully bonded)	3.20	73	4900
B1E20KV03185RD	3	185	70	15.80	4.50	0.50	0.40(fully bonded)	3.20	77	5400
B1E20KV03240RD	3	240	70	18.10	4.50	0.50	0.40(fully bonded)	3.20	82	6200

ELECTRICAL CHARACTERISTICS

Single Core

NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL SHORT-CIRCUIT OF CONDUCTOR CURRENT FOR 1 SECOND kA	MAXIMUM CONDUCTOR DC RESISTANCE AT 20°C Ω/km	CONDUCTOR AC RESISTANCE BY MAXIMUM TEMPERATURE Ω/km	CURRENT CARRYING CAPACITY A		CONDUCTOR LOSSES IN THE GROUND kW/km
				In Ground 20°C	In Air 30°C	
50	4.70	0.0641	0.825	195	217	31.4
70	6.58	0.0443	0.570	237	270	32.0
95	8.93	0.320	0.412	282	328	32.8
120	11.28	0.253	0.328	320	378	33.6
150	14.10	0.206	0.268	353	425	33.4
185	17.39	0.164	0.213	396	485	33.4
240	22.56	0.125	0.163	457	573	34.0
300	28.20	0.100	0.132	511	652	34.5
400	37.60	0.0778	0.103	566	740	33.0
500	47.00	0.0605	0.0810	630	838	32.1
630	59.22	0.0469	0.0640	701	882	-

Click here for more information:
elandcables.com | [YMz1Krvasdlwd-AL 12/20kV Cable](#)

ELAND
CABLES

ELECTRICAL CHARACTERISTICS

Multi Core

NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL SHORT-CIRCUIT OF CONDUCTOR CURRENT FOR 1 SECOND kA	MAXIMUM CONDUCTOR DC RESISTANCE AT 20°C Ω/km	CONDUCTOR AC RESISTANCE BY MAXIMUM TEMPERATURE Ω/km	CURRENT CARRYING CAPACITY A	
				In Ground 20°C	In Air 30°C
50	4.70	0.641	0.825	167	167
70	6.58	0.443	0.570	205	208
95	8.93	0.320	0.412	244	251
120	11.28	0.253	0.328	279	291
150	14.10	0.206	0.268	312	329
185	17.39	0.164	0.213	355	379
240	22.56	0.125	0.163	412	446


The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.

ATTACHMENT VI. MV/LV transformer **datasheet**


Combine the Freemaq PCSK &
Multi PCSK with our **MV solutions**.

MV Skid Compact & Twin Skid Compact

From low to medium voltage



MV SKID COMPACT
Page. 32 – 33



TWIN SKID COMPACT

Twin Skid Compact

RATINGS	Power range @ 40 °C	3050 kVA - 8780 kVA
	Power range @ 50 °C	2830 kVA - 8150 kVA
	MV voltage range	6.6 kV / 11 kV / 13.2 kV / 15 kV / 20 kV / 22 kV / 23 kV / 25 kV / 30 kV / 33 kV / 34.5 kV
	LV voltage range	480 V / 500 V / 530 V / 600 V / 615 V / 630 V / 645 V / 660 V / 690 V
	Transformer cooling	ONAN
	Transformer vector group	Dy11y11
MEDIUM VOLTAGE EQUIPMENT	Transformer protection	Protection relay for pressure, temperature (two levels) and gassing. Monitoring of dielectric level decrease. PT100 optional.
	Transformer index of protection	IP54
	Transformer losses	IEC standard or IEC Tier-2.
	Oil retention tank	Galvanized steel. Integrated with hydrocarbon filter. Optional
	Switchgear configuration	Double feeder (2L)
	Switchgear protection	Circuit breaker (V)
	Switchgear short circuit rating ^[1]	16 kA 1 s
	Switchgear IAC ^[1]	A FLR 16 kA 1 s
	LV-MV connections	Close coupled solution (plug & play)
	LV protection	Motorized circuit breaker included in the inverter
CONNECTIONS	HV AC wiring	MV bridge between transformer and protection switchgear prewired
	Ambient temperature range ^[2]	-10 °C... +50 °C (T > 50 °C power derating)
ENVIRONMENT	Maximum altitude (above sea level) ^[1]	Up to 1000 m
	Relative humidity	4% to 95% non condensing
AUXILIARY SERVICES ELECTRICAL PANEL	User power supply options	5 kVA / 40 kVA at 400 V (3-phase), 50 / 60 Hz (Integrated in the inverter)
	User cabinet	Integrated in the inverter (by default). Optionally, LV cabinet in the skid.
	Cooling	Forced air
	HW communication	Ethernet (fiber optic or RJ45)
	UPS system ^[1]	1 kVA/0.8 kW (10 minutes). Optional
OTHER EQUIPMENT	Safety mechanism	Interlocking system
	Fire extinguishing system	Transformer oil tank retention accessory. Optional.
STANDARDS	Compliance	IEC 62271-212, IEC 62271-200, IEC 60076, IEC 61439-1

NOTES

- [1] Consult with Power Electronics for other options.
[2] For lower temperatures, consult with Power Electronics.

ATTACHMENT VII. Software list

- **PVSyst**

Simulating the solar plant's model and providing results.

- **Meteonorm**

Obtaining solar irradiance data in order to simulate the model with these as input.

- **NASA**

Obtaining solar irradiance data in order to compare them with the ones provided by Meteonorm, thus discerning the most appropriate set of data.

- **Google Earth**

Obtaining global coordinates to later obtain solar irradiance data, hence discerning the best location for the project.

- **Matlab**

Elaborating *Figure 36*

- **SolidEdge**

Elaborating the project plans

ATTACHMENT VIII. Matlab algorithm for
***Figure 36* elaboration**

```
clear all
clc
close all force

X=[42.19
64.43
36.96
37.01
49.93
47.23
44.26
42.13
50.32
39.67
52.24
57.29
47.68
33.96
111.93
];

boxplot(X, 'Notch', 'on')
grid on
title('Yearly electricity price data distribution')
ylabel('Electricity Price (EUR/MWh)')
```

ATTACHMENT IX. Official PVSyst output tabs

Field type **Tracking, horizontal axis N-S**

Axis and limiting angles

Axis Tilt


Axis azimuth

Phi min.


Phi max.

Central gap

Axis Tilt 0°



Axis azimuth 0°



Special Behaviors

Backtracking

Irradiance optimization

Backtracking parameters

These values are defined in the 3D shadings scene

Pitch **12.00 m**


Collector width **4.42 m**

Left inactive band **0.00 m**

Right inactive band **0.00 m**

GCR (frame) **36.8%**

Rotating phi limits -55°/55°



Facing Axis azimuth = 0°

Output tab 1: Orientation settings (Source: PVSyst)

Sub-array

Sub-array name and Orientation
Name: Conjunto PV
Orient: Tracking, horizontal axis N-S

Pre-sizing Help
 No sizing

Select the PV module
Available Now: Longi Solar
Filter: All PV modules
Bifacial module: Bifacial system
Sizing voltages: Vmpp (60°C) 35.6 V, Voc (-10°C) 54.0 V

Select the inverter
Output voltage 660 V Tri 50Hz
Siemens 4800 kW 962 - 1500 V TL 50/60 Hz Sinacon PV4800
Nb of MPPT inputs: 20
Use multi-MPPT feature:

Design the array
Number of modules and strings
Mod. in series: 27
Nb. strings: 3494
Nb. modules: 94338 Area: 241132 m²

Operating conditions
Plane irradiance: 1000 W/m²
Vmpp (60°C): 962 V
Vmpp (20°C): 1119 V
Voc (-10°C): 1458 V
Imp (STC): 45708 A
Isc (STC): 47903 A
Max. operating power (at 1000 W/m² and 50°C): 45830 kW
Array nom. Power (STC): 49999 kWp


List of subarrays

Name	#Mod #Inv.	#String #MPPT
Conjunto PV		
Longi Solar - LRS-72 HBD 530 M Bifacial	27	3494
Siemens - Sinacon PV4800	10	20


Global system summary

Nb. of modules: 94338
Module area: 241132 m²
Nb. of inverters: 10
Nominal PV Power: 49999 kWp
Maximum PV Power: kWDC
Nominal AC Power: 48000 kWAC
Prom ratio: 1.042

Output tab 2: Modules and inverters settings (Source: PVSyst)



Output tab 3: Bifacial menu – General tracking settings (Source: PVSyst)



Output tab 4: Modules setting menu (Source: PVSyst)

Main parameters | Efficiency curve | Additional parameters | Output parameters | Sizes and Technology | Commercial data

Model: Sinacon PV4800 | Manufacturer: Siemens
 File name: Siemens_Sinacon_PV4800.OND | Data source: Manufacturer 2019
 Original PVsyst database | Prod. Since 2017

Input side (DC PV field)

Minimum MPP Voltage: 962 V
 Min. Voltage for PNom: N/A V
 Maximum current per MPPT: N/A A
 Nominal MPP Voltage: N/A V
Maximum MPP Voltage: 1500 V
Absolute max. PV Voltage: 1500 V
Power Threshold: 2000 W Default ?

Contractual specifications, without real physical meaning: ? Required

Nominal PV Power: 4836 kW
 Maximum PV Power: 9600 kW
 Maximum PV Current: 6400 A

Output side (AC grid)


Monophased
 Triphased
 Biphased

Frequency: 50 Hz 60 Hz

Grid voltage: 660 V
Nominal AC Power: 4800 kVA
 Maximum AC Power: 4800 kVA
 Nominal AC current: 4200 A
 Maximum AC current: 4200 A

Efficiency
Maximum efficiency: 98.92%
 Efficiency defined for 3 voltages

Output tab 5: Inverters setting menu (Source: PVSyst)



Output tab 6: Array sizing menu (Source: PVSyst)

Thermal parameter Ohmic Losses Module quality - LID - Mismatch Soiling Loss IAM Losses Auxiliaries Aging Unavailability Spectral correction

DC circuit: ohmic losses for the array

Specified by

Global wiring resistance 0.2412 mΩ Calculated Detailed computation

Loss fraction at STC 1.00 % Default

Voltage Drop across series diode 0.0 V Default

AC losses after the inverter

AC Wire loss Inverter to transfo (per inverter)

Uses AC circuit ohmic loss

Length Inverter to Transformer 9.2 m Wire section 4000 mm²

Loss fraction at STC 0.08 %

STC: Pac = 4926 kW, Vac = 660 V Tr1, I = 4309 A

Voltage drop at STC 0.5 V (0.08%)

Uses one or several MV transformers

Uses a HV transformer

Medium Voltage line (each transfo)

MV line voltage 20.0 kV

Length MV Transfo to injection 1000 m Wire section 300 mm²

Loss fraction at STC 0.32 %

STC: Pac = 12315 kW, Vac = 20.0 kV Tr1, I = 356 A

Voltage drop at STC 64.7 V (0.32%)

Medium and High voltage transformers

HV Transformer(s), full system

Number of MV transfos 4 night disconnect

Generic values

Reference Pac(STC) 12.32 MW

Iron loss (constant value) 0.20 % 24.63 kW default

Copper (resistive) loss 0.80 % at STC default

Transformo equivalent resistance 3 x 0.28 mΩ/inverter

Transformer from Datasheets

Uses datasheets data

Nominal power N/A MVA

Iron losses (no load loss) N/A MVA

Copper (resistive) loss at PNom N/A MVA

Global loss at PNom N/A MVA

Global efficiency at PNom N/A %

Losses graph Cancel OK

Output tab 7: Ohmic losses – electrical system design tab (Source: PVSyst)

Thermal parameter Ohmic Losses Module quality - LID - Mismatch Soiling Loss IAM Losses Auxiliaries Aging Unavailability Spectral correction

Uses degradation in the simulation

Uses in simulation

Parameters in simulation

Simulation for year no 1

Individual PV modules: Global degrad. factor 0.23 %

Mismatch degrad. factor 0.00 %

PV module aging parameters

Aver. degradation factor 0.45 %/year

Imp RMS dispersion 0.00 %/year

Vmp RMS dispersion 0.00 %/year

Store the Monte Carlo values

Monte-Carlo values

Mismatch 5 years N/A

Mismatch 10 years N/A

Mismatch 15 years N/A

Mismatch 20 years N/A

Mismatch 25 years N/A

Read model

Save as model

Add statistics

Used for this evaluation

Sub-array

27 Modules in series

175 Strings in parallel

Monte-Carlo calculation

2 Trials

1 years Random evaluation

0.00% Aver. Mismatch loss

0.00% Mismatch loss RMS

Module warranty

Year 0 Warranty 98.00 % PNom

Year 10 Warranty 91.00 % Linear interpol.

Year 20 Warranty 84.00 % Linear interpol.


Year 25 Warranty 80.00 % PNom

Average -0.72%/year

Draw: Curve Steps

The initial derate value (usually around -3%) may corresponds to the LID or initial tolerance.

Losses graph Cancel OK



Output tab 8: Aging losses menu (Source: PVSyst)

Close Print Export Help

Recompute

Plane orientation


Tracking, horizontal axis N-S

With Backtracking


Shading factor table (linear), for the beam component, Orient. #1

Azimuth	-180°	-160°	-140°	-120°	-100°	-80°	-60°	-40°	-20°	0°	20°	40°	60°	80°	100°	120°	140°	160°	180°
Height																			
90°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
80°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
70°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
60°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
50°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
40°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2°	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000


Output tab 9: Shading factor table with backtracking activated (Source: PVSyst)



Output tab 10: Plane orientation – Tracking, horizontal axis N-S (Source: PVSyst)




Output tab 11: Tracking settings menu (Source: PVSyst)



Output tab 12: Simulation graphs – elaborated while running simulation (Source: PVSyst)

ATTACHMENT X. Natural spaces
currently protected under Spanish law



ATTACHMENT XI. Gantt diagram

	Month 1				Month 2				Month 3				Month 4				Month 5				Month 6				Month 7				Month 8				Month 9				Month 10				Month 11				Month 12			
	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4
Basic Engineering																																																
Basic Project																																																
Environmental Impact Evaluation																																																
Detail Engineering																																																
Civil Works																																																
Electrical Facilities																																																
Construction and Assembly																																																
Roads																																																
Ditches																																																
Trackers																																																
Others																																																
Electrical Facilities																																																
LV cables and auxiliaries																																																
MV cables and auxiliaries																																																
Electrical Substation MV/HV																																																
Overhead Electrical Line HV																																																
PV Modules																																																
Starting Process																																																
Tests																																																
Provisional Reception																																																


ATTACHMENT XII. Acronym table

Acronym	Meaning
LV	<i>Low Voltage</i>
MV	<i>Medium Voltage</i>
HV	<i>High Voltage</i>
DC	<i>Direct Current</i>
AC	<i>Alternating Current</i>
EPR	<i>Ethylene Propylene Rubber</i>
XLPE	<i>Cross-Linked Polyethylene</i>
HEPR	<i>Hard-grade Ethylene Propylene Rubber</i>
STC	<i>Standard Test Conditions</i>
PV	<i>Photovoltaic</i>
GHI	<i>Global Horizontal Irradiance</i>
DHI	<i>Diffuse Horizontal Irradiance</i>
GCR	<i>Ground Coverage Ratio</i>
EPC	<i>Engineering, Procurement, and Construction</i>
O&M	<i>Operation and Maintenance</i>
WACC	<i>Weighted Average Cost of Capital</i>
NPV	<i>Net Present Value</i>
IRR	<i>Internal Rate of Return</i>

DOCUMENT II. PROJECT PLANS


INDEX

- **Site view.....116**
- **Site view: Location and Substation.....117**



MATERIAL	-		Final Degree Project	
TOLERANCIA	-		Site view	
DIBUJADO	M.C.O	NOMBRE	FECHA	I.C.A.I.
COMPROBADO			8/4/22	
HEIGHT:	40.25 km	FIRMA:		Nº DE LÁMINA:
				1

SOLID EDGE ACADEMIC COPY



MATERIAL	-		Final Degree Project	
TOLERANCIA	-		Site view: Location and Substation	
DIBUJADO	M.C.O	NOMBRE	FECHA	I.C.A.I.
COMPROBADO			8/4/22	
HEIGHT:	18.10 km	FIRMA:		Nº DE LÁMINA:
				2

SOLID EDGE ACADEMIC COPY

DOCUMENT III. CASH FLOW TABLES

INDEX

1. Cash flow table for years 0 to 5.....	120
2. Cash flow table for years 6 to 10.....	121
3. Cash flow table for years 11 to 15.....	122
4. Cash flow table for years 16 to 20.....	123
5. Cash flow table for years 21 to 25.....	124
6. Cash flow table for years 26 to 30.....	125

1. Cash flow table for years 0 to 5

Profit and Loss Account (EUR)		Year	0	1	2	3	4	5
<i>Operating Income</i>				4,604,676.43	4,632,101.68	4,654,913.03	4,682,466.36	4,710,105.26
-Operating Costs				504,000.00	511,560.00	519,233.40	527,021.90	534,927.23
- Generation Tax (7% on income)				322,327.35	324,247.12	325,843.91	327,772.65	329,707.37
-Amortization				2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91
Profits before tax				1,751,864.17	1,769,809.65	1,783,350.81	1,801,186.90	1,818,985.75
Free Cash Flow (EUR)		Year	0	1	2	3	4	5
=Profit before tax				1,751,864.17	1,769,809.65	1,783,350.81	1,801,186.90	1,818,985.75
- Corporation Tax (-25 %)				437,966.04	442,452.41	445,837.70	450,296.73	454,746.44
+Amortization				2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91
-Fixed Asset Investment			-31,152,040.00					
-Operating Funds Requirement Investment (7% on income)				322,327.35	324,247.12	325,843.91	327,772.65	329,707.37
-Free Cash Flow (FCF)			-31,152,040.00	3,018,055.69	3,029,595.03	3,038,154.11	3,049,602.44	3,061,016.85

2. Cash flow table for years 6 to 10

Profit and Loss Account (EUR)		Year	6	7	8	9	10
<i>Operating Income</i>			4,732,984.28	4,760,742.72	4,783,641.26	4,811,512.89	4,834,422.48
-Operating Costs			542,951.14	551,095.41	559,361.84	567,752.26	576,268.55
- Generation Tax (7% on income)			331,308.90	333,251.99	334,854.89	336,805.90	338,409.57
-Amortization			2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91
Profits before tax			1,832,239.34	1,849,910.42	1,862,939.63	1,880,469.82	1,893,259.45
Free Cash Flow (EUR)		Year	6	7	8	9	10
=Profit before tax			1,832,239.34	1,849,910.42	1,862,939.63	1,880,469.82	1,893,259.45
- Corporation Tax (-25 %)			458,059.83	462,477.61	465,734.91	470,117.45	473,314.86
+Amortization			2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91
-Fixed Asset Investment							
-Operating Funds Requirement Investment (7% on income)			331,308.90	333,251.99	334,854.89	336,805.90	338,409.57
-Free Cash Flow (FCF)			3,069,355.51	3,080,665.73	3,088,834.74	3,100,031.37	3,108,019.92

3. Cash flow table for years 11 to 15

Profit and Loss Account (EUR)		Year	11	12	13	14	15
<i>Operating Income</i>			4,862,400.63	4,890,454.90	4,913,390.15	4,941,540.87	4,969,763.26
-Operating Costs			584,912.58	593,686.26	602,591.56	611,630.43	620,804.89
- Generation Tax (7% on income)			340,368.04	342,331.84	343,937.31	345,907.86	347,883.43
-Amortization			2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91
Profits before tax			1,910,635.10	1,927,951.88	1,940,376.38	1,957,517.67	1,974,590.03
Free Cash Flow (EUR)		Year	11	12	13	14	15
=Profit before tax			1,910,635.10	1,927,951.88	1,940,376.38	1,957,517.67	1,974,590.03
- Corporation Tax (-25 %)			477,658.78	481,987.97	485,094.09	489,379.42	493,647.51
+Amortization			2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91	2,026,484.91
-Fixed Asset Investment							
-Operating Funds Requirement Investment (7% on income)			340,368.04	342,331.84	343,937.31	345,907.86	347,883.43
-Free Cash Flow (FCF)			3,119,093.19	3,130,116.98	3,137,829.88	3,148,715.30	3,159,544.00

4. Cash flow table for years 16 to 20

Profit and Loss Account (EUR)		Year	16	17	18	19	20
<i>Operating Income</i>			4,992,704.70	5,021,012.75	5,043,928.89	5,072,314.63	5,100,763.70
-Operating Costs			630,116.96	639,568.72	649,162.25	658,899.68	668,783.18
- Generation Tax (7% on income)			349,489.33	351,470.89	353,075.02	355,062.02	357,053.46
-Amortization			754,766.38				
Profits before tax			3,258,332.02	4,029,973.14	4,041,691.62	4,058,352.93	4,074,927.07
Free Cash Flow (EUR)		Year	16	17	18	19	20
=Profit before tax			3,258,332.02	4,029,973.14	4,041,691.62	4,058,352.93	4,074,927.07
- Corporation Tax (-25 %)			814,583.01	1,010,422.90	1,010,422.90	1,014,588.23	1,018,731.77
+Amortization			754,766.38				
-Fixed Asset Investment							
-Operating Funds Requirement Investment (7% on income)			349,489.33	351,470.89	353,075.02	355,062.02	357,053.46
-Free Cash Flow (FCF)			2,849,026.07	2,671,008.96	2,678,193.69	2,688,702.67	2,699,141.84

5. Cash flow table for years 21 to 25

Profit and Loss Account (EUR)		Year	21	22	23	24	25
<i>Operating Income</i>			5,123,650.32	5,152,165.03	5,175,000.43	5,203,571.94	5,232,197.38
-Operating Costs			678,814.92	688,997.15	699,332.10	709,822.09	720,469.42
- Generation Tax (7% on income)			358,655.52	360,651.55	362,250.03	364,250.04	366,253.82
-Amortization							
Profits before tax			4,086,179.87	4,102,516.33	4,113,418.30	4,129,499.82	4,145,474.15
Free Cash Flow (EUR)		Year	21	22	23	24	25
=Profit before tax			4,086,179.87	4,102,516.33	4,113,418.30	4,129,499.82	4,145,474.15
- Corporation Tax (-25 %)			1,021,544.97	1,025,629.08	1,028,354.57	1,032,374.95	1,036,368.54
+Amortization							
-Fixed Asset Investment							
-Operating Funds Requirement Investment (7% on income)			358,655.52	360,651.55	362,250.03	364,250.04	366,253.82
-Free Cash Flow (FCF)			2,705,979.38	2,716,235.70	2,722,813.69	2,732,874.83	2,742,851.79

6. Cash flow table for years 26 to 30

Profit and Loss Account (EUR)		Year	26	27	28	29	30
<i>Operating Income</i>			5,254,963.88	5,283,632.69	5,306,319.47	5,335,021.84	5,363,767.62
-Operating Costs			731,276.46	742,245.61	753,379.29	753,379.29	764,679.98
- Generation Tax (7% on income)			367,847.47	369,854.29	371,442.36	373,451.53	375,463.73
-Amortization							
Profits before tax			4,155,839.95	4,171,532.80	4,181,497.82	4,208,191.02	4,223,623.91
Free Cash Flow (EUR)		Year	26	27	28	29	30
=Profit before tax			4,155,839.95	4,171,532.80	4,181,497.82	4,208,191.02	4,223,623.91
- Corporation Tax (-25 %)			1,038,959.99	1,042,883.20	1,045,374.46	1,052,047.76	1,055,905.98
+Amortization							
-Fixed Asset Investment							
-Operating Funds Requirement Investment (7% on income)			367,847.47	369,854.29	371,442.36	373,451.53	375,463.73
Free Cash Flow (FCF)			2,749,032.49	2,758,795.31	2,764,681.00	2,782,691.74	2,792,254.20

